ELECTRONIC MEMORANDUM

From: **HEAD OF TRANSPORTATION and ENGINEERING**

To: **HEAD OF DEVELOPMENT CONTROL**

FAO **Case Officer:** Mark Taylor

Date: 18 November 2016

File Ref: E/DC/01/C

TE Ref: 7531 **Application No:** F/16/79132

Application Address: 1 Cambrian Close, Bursledon, Southampton, SO31 8GW

Application Summary: Erection of 2m high steel fence

CONSULTATION RESPONSES

Transport Policy Officer: Matt Grantham

TPol Comments: No objection providing all checks have been completed to ensure the land to be enclosed within the fence is private land under the ownership of the applicant.

DC Engineer: Eric Reed

DC Engineer Comments: It looks like the panels on south east side by the parking area would rerstrict use of the end parking space in the car court. I would recommend that panels there are set back at least 0.5m away from the end parking space to allow access to car doors.

Other Engineer: 0

Other Comments:

Transport Contribution Calculator

Year

No contribution required ☐

Contribution to be advised ☐

NB: All contributions subject to index linking

RESIDENTIAL

	No. of Properties			Contributions
	Exist	Prop	Diff	
1 bed	0	0	0	£0
2/3 bed	0	0	0	£0
4+ bed	0	0	0	£0

Total Residential Contribution £0

COMMERCIAL

	Size of Units (sqm)			Contributions
	Exist	Prop	Diff	
B1	0	0	0	£0
B2	0	0	0	£0
B8	0	0	0	£0

Total Commercial Contribution £0

Other Contribution £0.00

Other Contribution Reason

Total Sustainable Transport Contribution £0

Total Integrated Transport Contribution £0

Register Ref. 7531