ELECTRONIC MEMORANDUM

From: **HEAD OF TRANSPORTATION and ENGINEERING**

To: **HEAD OF DEVELOPMENT CONTROL**

FAO Case Officer: David Huckfield

Date: 11 August 2014

File Ref: E/DC/01/B

TE Ref: 6306 **Application No:** A/14/74834

Application Address: Sparshatts Of Botley Ltd, Broad Oak, Botley, Southampton, SO30 2EU

Application Summary: Display of 1no. Internally illuminated fascia sign, 1no. Non-illuminated vertical fascia sign, 1no. Part internally & part externally illuminated communication wall, 1no. Internally illuminated entrance statement sign, 1no. Internally illuminated pylon sign & 1no. Internally illuminated directional sign

CONSULTATION RESPONSES

Transport Policy Officer: Matt Grantham

TPol Comments: No objection.

Condition GN11: Luminance should not exceed 600 Cd/m2 and no light source should be visible from the highway. Reason: In the interests of highway safety/amenity.

DC Engineer: Eric Reed

DC Engineer Comments: No objection

Other Engineer: 0

Other Comments:

Transport Contribution Calculator

Year

No contribution required ☐

Contribution to be advised ☐

NB: All contributions subject to index linking

RESIDENTIAL

	No. of Properties			Contributions
	Exist	Prop	Diff	
1 bed	0	0	0	£0
2/3 bed	0	0	0	£0
4+ bed	0	0	0	£0

Total Residential Contribution £0

COMMERCIAL

	Size of Units (sqm)			Contributions
	Exist	Prop	Diff	
B1	0	0	0	£0
B2	0	0	0	£0
B8	0	0	0	£0

Total Commercial Contribution £0

Other Contribution £0.00

Other Contribution Reason

Total Sustainable Transport Contribution £0

Total Integrated Transport Contribution £0

Register Ref. 6306