Dimensions are not to be scaled from this drawing.



Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Min/Avg	Min/Max
Car Park	Illuminance	Lux	9.84	22	4	0.41	0.18
Spill Light	Illuminance	Lux	0.44	14	0	N.A.	N.A.

Luminaire Schedule				
Symbol	Qty	Label	Arrangement	Description
	3	RLK1042PL-P0	SINGLE	42w PL Kaos 1 Road lantern (P0 lamp position) column mounted at 4m

90°

Revision	Date	Description	Initials

Kingfisher Exterior Lighting

Members Of

HEMSA

ILP Institution of Lighting Professionals

Lighting Industry Association

SAFCA Ancillary Contractor

Contact Details

Ratcher Way, Crown Farm Industrial Park, Mansfield, Nottinghamshire. NG19 0FS
Design Telephone 01623 415 904 Fax. 01623 415 920
Email. light@kingfisherlighting.com
Web. www.kingfisherlighting.com

Project Title

The Midlands Estate, Southampton

Client

M R Electrical

Scale	Project No
1:200 at A2	D20490/JB/A
Date	**Drawing No**
18/7/2012	D20490/JB/A

A lighting applications design service is provided by us in good faith and without charge, relating to Kingfisher products only. As such, whilst every endeavour is made for accuracy from information provided by yourselves, the final responsibility for the suitability of the design lies with the client. The company cannot, therefore, accept any liability or consequential loss incurred.