



Job no:	4119
Date:	05/02/2021
Assessor name:	AES Sustainability Consultants
Registration no:	
Development name:	Boorley Green B3a

BRE Global 2010. BRE Certification is a registered trademark owned by BRE Global and may not be used without BRE Global's written permission.

Permission is given for this tool to be copied without infringement of copyright for use only on projects where a Code for Sustainable Homes assessment is carried out. Whilst every care is taken in preparing the Wat 1 assessment tool, BREG cannot accept responsibility for any inaccuracies or for consequential loss incurred as a result of such inaccuracies arising through the use of the Wat 1 tool.

PRINTING: before printing please make sure that in "Page Setup" you have selected the page to be as "Landscape" and that the Scale has been set up to 70% (maximum)

WATER EFFICIENCY CALCULATOR FOR NEW DWELLINGS - (BASIC CALCULATOR)

		House Type:		Type 1		Type 2		Type 3		Type 4		Type 5		Type 6		Type 7		Type 8		Type 9		Type 10	
		Description:		Private		Private (water saving bath)		Affordable Rental		Affordable Shared													
Installation Type		Unit of measure		Capacity/ flow rate	Litres/ person/ day	Capacity/ flow rate	Litres/ person/ day	Capacity/ flow rate	Litres/ person/ day	Capacity/ flow rate	Litres/ person/ day	Capacity/ flow rate	Litres/ person/ day	Capacity/ flow rate	Litres/ person/ day	Capacity/ flow rate	Litres/ person/ day	Capacity/ flow rate	Litres/ person/ day	Capacity/ flow rate	Litres/ person/ day	Capacity/ flow rate	Litres/ person/ day
Is a dual or single flush WC specified?				Dual		Dual		Dual		Dual		Select option:		Select option:		Select option:		Click to Select		Click to Select		Click to Select	
WC	Full flush volume	4	5.84	4	5.84	6	8.76	6	8.76		0.00		0.00		0.00		0.00		0.00		0.00		0.00
	Part flush volume	2.6	7.70	2.6	7.70	4	11.84	4	11.84		0.00		0.00		0.00		0.00		0.00		0.00		0.00
Taps (excluding kitchen and external taps)		Flow rate (litres / minute)	5	9.48	5	9.48	8.2	14.54	8.2	14.54		0.00		0.00		0.00		0.00		0.00		0.00	
Are both a Bath & Shower Present?				Bath & Shower		Bath & Shower		Bath & Shower		Bath & Shower		Select option:		Select option:		Select option:		Select option:		Select option:		Select option:	
Bath	Capacity to overflow	181	19.91	131	14.41	130	14.30	140	15.40		0.00		0.00		0.00		0.00		0.00		0.00		0.00
Shower	Flow rate (litres / minute)	5	21.85	5	21.85	6	26.22	6	26.22		0.00		0.00		0.00		0.00		0.00		0.00		0.00
Kitchen sink taps		Flow rate (litres / minute)	3.8	12.03	3.8	12.03	6	13.00	6	13.00		0.00		0.00		0.00		0.00		0.00		0.00	
Has a washing machine been specified?				No		No		No		No		Select option:		Select option:		Select option:		Select option:		Select option:		Select option:	
Washing Machine	Litres / kg		17.16		17.16		17.16		17.16		0.00		0.00		0.00		0.00		0.00		0.00		0.00
Has a dishwasher been specified?				No		No		No		No		Select option:		Select option:		Select option:		Select option:		Select option:		Select option:	
Dishwasher	Litres / place setting		4.50		4.50		4.50		4.50		0.00		0.00		0.00		0.00		0.00		0.00		0.00
Has a waste disposal unit been specified?				No		Select option:		No		No		Select option:		Select option:		Select option:		Select option:		Select option:		Select option:	
Water Softener	Litres / person / day		0.00		0.00		0.00		0.00		0.00		0.00		0.00		0.00		0.00		0.00		0.00
Calculated Use			98.5		93.0		110.3		111.4		0.0		0.0		0.0		0.0		0.0		0.0		0.0
Normalisation factor			0.91		0.91		0.91		0.91		0.91		0.91		0.91		0.91		0.91		0.91		0.91
Code for Sustainable Homes	Total Consumption		89.6		84.6		100.4		101.4		0.0		0.0		0.0		0.0		0.0		0.0		0.0
	Mandatory level		Level 3/4		Level 3/4	Level 3/4		Level 3/4		-		-		-		-		-		-		-	
Building Regulations 17.K	External use		5.0		5.0		5.0		5.0		5.0		5.0		5.0		5.0		5.0		5.0		5.0
	Total Consumption		94.6		89.6		105.4		106.4		0.0		0.0		0.0		0.0		0.0		0.0		0.0
	17.K Compliance?		Yes		Yes		Yes		Yes		-		-		-		-		-		-		-