

Linden Homes - Boorley Green B5 - MCS Zone 3 - 14,500 kWh Target

PLOT NO	ROOF INCLINE	VARIATION^o FROM SOUTH	OVERSHADING FACTOR	kWp	kWh
337	40	30	1	2.4	2385.60
338	40	30	1	2.4	2385.60
339	40	30	1	2.4	2385.60
357	40	50	1	4.2	3964.80
360	40	60	1	4.2	3830.40
Totals				15.6	14952

The Performance of solar PV systems is impossible to predict with certainty due to the variability in the amount of solar radiation (sunlight) from location to location and from year to year. This estimate, based upon the MCS procedure, is given as guidance only. It should not be considered as a guarantee of performance.

This system performance calculation has been undertaken using estimated value for array orientation, inclination or shading. Actual performance may be significantly lower or higher if the characteristics of the installed system vary from the estimated results.