

Air Permeability Test Certificate



This is to certify that the following test and results have been produced in compliance with England and Wales regulation 43 of the Building Regulations 2010, Scotland Section 6 of the Domestic and Non-Domestic Handbook, Northern Ireland Technical Booklet and Isle of Man The Building Control (Approved Documents) Order 2014. A full report in line with the current approved procedures can be requested from the iATS tester.

Unique Certificate Number	10227880
Test Method	Blower Door
Date of Test	25 th February 2022
Building name / Plot number	Highview
Building Address	Windmill Lane, Bursledon, Southampton, Hampshire SO31 8BG
r^2 (Correlation ≥ 0.98 - ≤ 1.00)	0.9950
n (Slope ≥ 0.5 - ≤ 1.0)	0.676
Envelope Area of Building m ²	382
Report Reference	0006144
Tester's Name	Lee Blanchard
Company Name	Southern Assessors
iATS Tester No.	0154
Tester's level of competence	Level 1: Buildings < 4000m ³
Related party disclosure	No related party
Signed	

Independent Airtightness Testing Scheme
16 St Johns Business Park,
Lutterworth,
Leicestershire, LE17 4HB

e: certificate@iats-uk.org
t: 0300 688 0016
w: iats-uk.org
Company Registration No: 09309058

	Calculated at 50 PA
Air permeability m ³ (h.m ²)	4.39
Air change rate (1/h)	N/A