



TITLE: PROPOSED DRAINAGE LAYOUT SHEET 03									
TECH: CL		CSE: <i>Chait</i>		ICSE: <i>Chait</i>		SCALE: 1:200		@ A1	
INITIAL ISSUE: 13/05/2021									
STATUS: CONSTRUCTION									
DRAWING No:									
PROJECT:	ORG:	ZONE:	LEVEL:	TYPE:	ROLE:	NUMBER:	REV:		
5015142	RDG	XX	ST	DR	C	0502	C09		

11. ALL PIPES UNDER THE BUILDING ARE TO BE DUCTILE IRON TO THE FIRST CHAMBER.
12. ALL PIPES EXTERNAL TO THE BUILDING TO BE PVCU.
13. ALL SVPS & SUB-STACKS TO HAVE ACCESS POINT MINIMUM OF 600mm ABOVE FFL TO PROVIDE RODDING ACCESS FOR UNDERGROUND PIPEWORK.
14. LOCATION OF DISCHARGE STACKS, RWP'S, SVPS & GULLEY LOCATIONS ARE INDICATIVE ONLY. REFER TO THE ARCHITECT & MEP ENGINEER DRAWINGS FOR LOCATIONS. THE CONTRACTOR SHALL DETERMINE FINAL SETTING OUT OF POP-UPS TO COORDINATE WITH THE ARCHITECT'S DRAWINGS.
15. ALL ELEVATIONS ARE IN METRES TO ORDNANCE DATUM UNLESS NOTED OTHERWISE.
16. ALL COVER LEVELS ARE APPROXIMATE & TO BE VERIFIED BY THE CONTRACTOR TO COORDINATE WITH SURROUNDING FINISHED FLOOR OR PAVEMENT SURFACE LEVELS.
17. ALL REDUNDANT PIPEWORK TO BE VERIFIED ON SITE & TRACED BY THE CONTRACTOR BEFORE COMMENCEMENT OF WORK.
18. THE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH THE DESIGNER'S RISK REGISTER FOR ANY IDENTIFIED POTENTIAL RISKS.