

 Proposed street lighting column (Unit Type ID displayed inside symbol. Unit reference number displayed outside symbol).

 Street lighting column proposed as part of phase 1 works.

Notes

1. Do not scale from drawing if not printed at original paper size.
2. Contractor to confirm position of statutory undertakers plant before commencement of the works. For statutory undertaker's information visit www.linesearchbeforeudig.co.uk
3. During works all traffic management to be in accordance with Chapter 8 of the Traffic Signs Manual.
4. Lighting columns to be fed by DNO supply unless otherwise shown.
5. Each luminaire to be fitted with a single 3 pin NEMA socket.
6. Columns to be numbered using adhesive labels suitable for exterior use. Letters and numerals shall be 50mm high black on a white background.
7. All apparatus are to be new at the time of installation and be supported by relevant manufacturer's guarantees.
8. All apparatus shall be sited so as to minimise, in so far as is reasonable and practical, nuisance, danger and obstruction to all residents, businesses and users of the highway.
9. All illuminated apparatus must be installed and tested in compliance with BS7671 at the time of adoption.
10. All installations must be installed in such a way that trees or any other foliage on the site does not interfere with the level of lighting.
11. This detailed design has been prepared in accordance with the HEA-HEMSA guidance note - CDM2015 regulations, issue 1.1, dated 09/04/15 Procedure 3: information has been supplied by the client or another designer or the principal designer which forms the basis of this lighting scheme design and includes the hazards identified by others on their hazard elimination and management list.

REV	DESCRIPTION	DATE	BY
-----	-------------	------	----

ENERVEO

Enerveo Lighting Design, 1st Floor, Solent Park, Walton
Road, Portsmouth, PO6 1UJ
email - lightingdesign@enerveo.com

TITLE PRIVATE LIGHTING LAYOUT DRAWING

PROJECT
BOTLEY ROAD, MOORGREEN
HEDGE END - PHASE 2

SCALE 1:500 @ A3	DATE	13/05/22
	DRAWN	MWG
	CHECKED	SAB

PAPER SIZE	A3	APPROVED	SAB
DRAWING NUMBER		REVISION	
EVO327284-LD-001-A		A	

Col Ref	Location	Easting	Northing	Electricity Supply
19	Road 01	447840.0	114641.0	DNO
20	Road 01	447809.1	114656.0	DNO
21	Road 01	447791.2	114669.8	DNO
22	Road 01	447806.0	114697.6	DNO
23	Road 01	447829.5	114690.6	DNO
24	Road 01	447861.4	114694.1	DNO
25	Road 01	447874.3	114669.2	DNO