



Development Control Services
Eastleigh Borough Council
Eastleigh House
Upper Market Street
Eastleigh
Hampshire
SO50 9YN

Your ref
H/22/93435

Our ref
DSA000014732

Date
22/08/2022

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Rear Conservatory linking house to detached garage.

Site: H/22/93435: - 2 Kingsmill Drive, Fair Oak, Eastleigh, SO50 7QE.

Thank you for your letter dated 03/08/2022.

Please see the attached extract from Southern Water records showing the approximate position of water distribution mains in the immediate vicinity of the development site. The exact position of the public assets must be determined on site by the applicant in consultation with Southern Water, before the layout of the proposed development is finalised.

- The 90 mm water distribution mains requires a clearance of 6 metres on either side of the water distribution mains to protect it from construction works and to allow for future access for maintenance.
- No excavation, mounding or tree planting should be carried out within 6 metres of the external edge of the public water distribution mains without consent from Southern Water.
- No new soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 metres of a public water distribution mains.
- All existing infrastructure, including protective coatings and cathodic protection, should be protected during the course of construction works.

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.



Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service: developerservices.southernwater.co.uk and please read our New Connections Charging Arrangements documents which are available on our website via the following link: southernwater.co.uk/developing-building/connection-charging-arrangements

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Business Channels

southernwater.co.uk/developing-building/planning-your-development