



Development Control Services
Eastleigh Borough Council
Eastleigh House
Upper Market Street
Eastleigh
Hampshire
SO50 9YN

Your ref
F/22/93473

Our ref
DSA000014388

Date
29/08/2022

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Demolition of the existing "Live Fire" training buildings and removal of the firefighting foam training pad on the site of the Hampshire & Isle of Wight Fire & Rescue Service Headquarters. Installation of new live fire training facilities and associated smoke filtration units. Construction of associated hardstanding and fencing to the perimeter.

Site: F/22/93473: - Hampshire Fire and Rescue Service Headquarters, Leigh Road, Eastleigh, Hampshire SO50 9SJ.

Thank you for your letter dated 22/07/2022.

Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service: developerservices.southernwater.co.uk and please read our New Connections Charging Arrangements documents which are available on our website via the following link: southernwater.co.uk/developing-building/connection-charging-arrangements

The developer can discharge surface water flow no greater than existing levels if proven to already be connected and it is ensured that there is no overall increase in flows into the surface water system. The developer will be required to provide a topographical site survey and/or a CCTV survey with the connection application showing the existing connection points, pipe sizes, gradients and calculations confirming the proposed surface water flow will be no greater than the existing contributing flows.

The supporting documents make reference to drainage using Sustainable Drainage Systems (SuDS).

Under certain circumstances SuDS will be adopted by Southern Water should this be requested by the developer. Where SuDS form part of a continuous sewer system, and are not an isolated end of pipe SuDS component, adoption will be considered if such systems comply with the latest Sewers for Adoption (Appendix C) and CIRIA guidance available here:

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670



water.org.uk/sewerage-sector-guidance-approved-documents/

[ciria.org/Memberships/The SuDS Manual C753 Chapters.aspx](http://ciria.org/Memberships/The_SuDS_Manual_C753_Chapters.aspx)

Where SuDS rely upon facilities which are not adoptable by sewerage undertakers the applicant will need to ensure that arrangements exist for the long-term maintenance of the SuDS facilities. It is critical that the effectiveness of these systems is maintained in perpetuity. Good management will avoid flooding from the proposed surface water system, which may result in the inundation of the foul sewerage system.

Thus, where a SuDS scheme is to be implemented, the drainage details submitted to the Local Planning Authority should:

- Specify the responsibilities of each party for the implementation of the SuDS scheme.
- Specify a timetable for implementation.
- Provide a management and maintenance plan for the lifetime of the development.

This should include the arrangements for adoption by any public authority or statutory undertaker and any other arrangements to secure the operation of the scheme throughout its lifetime.

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

Please note: There is 1250 mm private surface water culverted WC crossing in the site.

Land uses such as general hard standing that may be subject to oil/petrol spillages should be drained by means of appropriate oil trap gullies or petrol/oil interceptors.

The Trade Effluent application process for non-household (NHH) customers has changed since April 2017. This was a government decision to open the Market to competition.

In order to apply for a consent, you will need to engage a Retailer and submit the application through them.

Southern Water (SWS) is still the owner of assets (Wholesaler), but all administrative or billing matters are conducted by the Retailer of your choice.

Attached is a link to the Open Water website that lists Retailers available. Please note that not all Retailers will provide a Trade Effluent service. open-water.org.uk/for-customers/find-a-retailer/suppliers/english-water-and-wastewater-retailers

Once we have received an application via your appointed water retailer, we have 2 months to issue a consent or refuse the application. Any requirement to discharge directly to the environment will require a permit/consent from the Environment Agency.



Should the Local Planning Authority be minded granting planning permission for this development we request that the following condition is attached to the consent: The applicant should ensure that the Trade Effluent discharge licence has been obtained, before the connection to the public sewerage network can be approved.

We request that should this planning application receive planning approval, the following informative is attached to the consent: Construction of the development shall not commence until details of the proposed means of foul sewerage and surface water disposal have been submitted to, and approved in writing by, the Local Planning Authority in consultation with Southern Water.

This initial assessment does not prejudice any future assessment or commit to any adoption agreements under Section 104 of the Water Industry Act 1991. Please note that non-compliance with Sewers for Adoption standards will preclude future adoption of the foul and surface water sewerage network on site. The design of drainage should ensure that no groundwater or land drainage is to enter public sewers.

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Business Channels

southernwater.co.uk/developing-building/planning-your-development