

Osmond, Gary

From: Pyke, Jon
Sent: 23 September 2022 12:04
To: Osmond, Gary
Cc: Scott, Neil
Subject: Application No: F/22/93356 - Address: 59 POUND ROAD, BURSLEDON, SOUTHAMPTON, SO31 8FF

Description: Construction of 1no. 2 bedroom detached dwelling (Amended Design)

Hi Gary

Thank you for consulting Pollution Control for observations on this application. These are:

1. Smooth paved hardscape and access is preferable as opposed to say to loose stones or granula material to minimise noise to existing dwellings, as well as a close boarded boundary fence (15 kg/m2) or masonry wall to 2m in height around the boundary.
2. Design of outdoor artificial to be sympathetic to the setting , warm in colour (at 3000K) and of course complying with the Institution of Lighting Engineers' "Guidance Note 1 for the reduction of obtrusive light"
3. Construction stage environmental impacts managed through a Construction and Environmental Management Plan in proportionate detail.

We trust this is clear and helpful. Let me know if you gave a question.

Kind regards
Jon

Jon Pyke

Pollution Control Officer

Service Delivery - Specialist Services - Environment

-----Original Message-----

From: Neil Scott <neil.scott@eastleigh.gov.uk>
Sent: 15 September 2022 17:09
To: Pyke, Jon <Jon.Pyke@eastleigh.gov.uk>
Subject: Process transferred to you.

Process PR202209-96071 has been assigned to you. Please click on the link below to view the record.

<https://staffhub.eastleigh.gov.uk/a2Q4J00000B1rC9>