

From: [Tim Dyer](#)
To: [Campbell-Best, Claire](#)
Subject: H/22/93707 - 22 Crowsport, Hamble-le-Rice, SO31 4HG.
Date: 17 October 2022 11:51:39

Claire,

Good to see that a big heat sink affecting the whole of the living space of this house is to be removed. No objection in principle but just two items :-

1. The head of the new window needs to be level with that of the window/door to the left at first floor level. What is proposed has the effect of increasing the apparent height of the overall building whereas having it at the same level maintains the existing status quo.

2. There is no detail of the proposed windows. We need to be sure there are no unnecessary glazing bars proposed, to be in line with the Conservation Area document.

Holding objection.

Regards,

Tim.

--

Tim J S Dyer, B.Sc.,Dip.Arch.(Birm), Grad.Dip.Conservation(AA), RIBA.

[Built Heritage Consultant.](#)