

Ecology response for H/22/94037 19 TWYFORD ROAD, EASTLEIGH, SO50 4HD

Single storey side/rear extension. First floor internal alterations Alterations to fenestrations.
Replace existing garage with carport and integral store

Dorothy Hei-Tung-Hoh

16/11/22

There are records of bats very near this site, however I don't think this proposal is likely to affect any potential bat roost features.

Please could you add the following informative to the decision notice:

In the unlikely event of any bats being found during demolition or construction, all work must stop immediately, and Natural England must be informed. Additional information is available on the Bat Conservation Trust website at <https://www.bats.org.uk/advice/im-working-on-a-building-with-bats/ive-found-a-bat-during-works>.

Biodiversity enhancements are required. This property is likely to have a north or northeast elevation available so a swift nest box might be appropriate.

Swift nest boxes are best positioned under the eaves or on walls facing north, northeast or north-west out of direct sunlight, five metres above the ground, with clear adjacent airspace so swifts can access them in a high-speed direct flight.

(<https://www.swiftconservation.org/Nestboxes%26Attraction.htm>)

Additional information is available at:

<https://sussexwildlifetrust.org.uk/discover/in-your-garden/article/31>, planting for bats

<https://www.rhs.org.uk/science/conservation-biodiversity/wildlife/plants-for-pollinators>

<https://www.bats.org.uk/our-work/buildings-planning-and-development/bat-boxes>

<https://www.hampshireswifts.co.uk/nesting>

<https://www.rspb.org.uk/birds-and-wildlife/advice/how-you-can-help-birds/nestboxes/nestboxes-for-small-birds/>

<https://www.swift-conservation.org/OurLeaflets.htm>

Lisa Malter

Ecologist