



Development Control Services
Eastleigh Borough Council
Eastleigh House
Upper Market Street
Eastleigh
Hampshire
SO50 9YN

Your ref
H/22/94127

Our ref
DSA000018058

Date
02/12/2022

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Retention of fence and a gate.

Site: H/22/94127: - Maple Ridge, Winchester Road, Fair Oak, Eastleigh SO50 7HA.

Thank you for your letter dated 11/11/2022.

Southern Water would have no objections to the above proposal.

Please see the attached extract from Southern Water records showing the approximate position of our existing public foul rising main in the development site.

Please note:

- The 100 mm public foul rising main requires a clearance of 3 metres on either side of the public foul rising main to protect it from construction works and to allow for future maintenance access.
- No development or tree planting should be carried out within 3 metres of the external edge of the public foul rising main without consent from Southern Water.
- No soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 metres of a public foul rising main.
- All existing infrastructure should be protected during the course of construction works.

Please refer to: southernwater.co.uk/media/3011/stand-off-distances.pdf

Furthermore, it is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.



For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Business Channels

southernwater.co.uk/developing-building/planning-your-development