

Altman, Rebecca

Subject: FW: FAO Thomas Callaway - 14 High Street, Eastleigh - conditions app ref. DC/22/94052; app ref. F/20/89125

From: FWM Statutory SWM Consultee mailbox <SWM.Consultee@hants.gov.uk>
Sent: 21 December 2022 14:48
To: Altman, Rebecca <rebecca.altman@eastleigh.gov.uk>
Cc: FWM Statutory SWM Consultee mailbox <SWM.Consultee@hants.gov.uk>
Subject: RE: FAO Thomas Callaway - 14 High Street, Eastleigh - conditions app ref. DC/22/94052; app ref. F/20/89125

Dear Rebecca

Thank you for consulting us on this additional information.

I am happy with most of the designer's response, I was not aware of earlier additional correspondence between the applicant and my colleague that addressed some of the points.

We do however require the evidence for the proposed discharge rate. This is important as we would not want to force the water company into accepting a rate that they may not agree to. Additionally, if the rate were to change, it would affect the attenuation storage requirements for the site. Therefore we maintain the holding objection until Southern Water have confirmed those details are acceptable.

Regards

Tom Callaway

From: Altman, Rebecca <rebecca.altman@eastleigh.gov.uk>
Sent: 09 December 2022 11:24
To: FWM Statutory SWM Consultee mailbox <SWM.Consultee@hants.gov.uk>
Subject: FAO Thomas Callaway - 14 High Street, Eastleigh - conditions app ref. DC/22/94052; app ref. F/20/89125

Caution: This is an external email and could contain malicious content. Do not open any links or attachments if you were not expecting them. If the e-mail looks suspicious, please report via the 'Report Phishing' Button found on your toolbar.

Dear Thomas

14 High Street, Eastleigh – Condition 6 – conditions app ref. DC/22/94052, app ref. F/20/89125

Further to your comments regarding condition 6 of the above application, I have now received the attached further information from the applicants (Designers response and updated Drainage Strategy layout plan).

Please can you review this information and provide your comments by 23 December 2022.

Thank you

Rebecca

Rebecca Altman
Principal Planning Officer

Working days - Wed-Fri
023 8068 8266



Eastleigh Borough Council | Eastleigh House | Upper Market Street | Eastleigh | SO50 9YN



This email is subject to recording and/or monitoring. Any content or attachments are for the person to whom it is addressed and may be confidential.
If you get it by mistake, please email us back as soon as possible, and then delete it from your system; please do not pass it on to anyone else or use the information in it.
We do our best to guard against viruses. If you get a virus, we cannot accept liability for any damage. You should carry out your own virus check before you open attachments.

Eastleigh Borough Council