

Ecology response for F/22/94433 57 SHAKESPEARE ROAD, EASTLEIGH, SO50 4FY

Erection of a detached two bed dwelling, with associated parking access and cycle store (Resubmission of application F/22/92867).

Summer Sharpe

19/1/23

The ecology information submitted for the previous application is the same, with new boundary hedging proposed to the front of the site and tree planting, bat and bird boxes provided within the site. Hedging is not shown on any of the 3-D proposed street scene drawings.

This ecology response is the same as for the previous application:

The boundary hedging and trees should be flowering native species that will provide resources for pollinators and fruit for birds and other wildlife. Bat and bird boxes should be built into the building if possible, rather than externally mounted. The use of a flowering lawn mixture is preferred over amenity turf.

Any closed board fencing should have 13 x 13cm gaps in the baseboards to allow the passage of small mammals such as hedgehogs between neighbouring gardens.

This application requires a surface water drainage plan. If a soakaway is proposed, it must be at least 5 m from any building and supported by infiltration testing. This may not be possible on such a small site.