

Harrison, Liz

From: Pyke, Jon
Sent: 23 January 2023 12:21
To: Harrison, Liz
Cc: Scott, Neil
Subject: Application No: DC/23/94478 Address: Land North West of Winchester Road, Boorley Green, Hampshire, SO32 2BX,

Description: Discharge of conditions 16 (noise assessment) & 22 (ecological protection & mitigation plan) of planning permission O/15/75953 as amended by X/19/84943 for development of a new sustainable neighbourhood comprising of up to 680 residential units, a new local centre including provision for small scale retail and/or community/healthcare use, land for a two-form entry primary school, formal and informal open space and sports provision, access roads and all other associated and necessary on-site infrastructure including details of the new junction arrangement for the main point of access into the development

Good afternoon, Liz

Thank you for consulting Pollution Control for observations.

(1) We should like to confirm with the applicant, the following will be installed to all dwellings

- Pilkington Insulated glass unit being 4mm / 6 to 16mm / 4mm or better

(2) We understand from the Addendum the following will be installed to all dwellings, and this must have equal or better than a V75/C75. We seek the applicant's confirmation.

- Triton Trickle V 25 Vent
- Sound insulation information for this product type. Details on V75 / C75 and Std. Vent / C25 were provided in report reference SA-5241-5A "Environmental Noise Impact Assessment" dated March 2020

Let me know when the information is received for me to complete our consultation response.

Kind regards

Jonathan

Jon Pyke

Pollution Control Officer

Service Delivery - Specialist Services - Environment