

Stone, Alexandra

From: Tim Dyer [REDACTED]
Sent: 01 February 2023 11:54
To: Stone, Alexandra <Alexandra.Stone@eastleigh.gov.uk>
Subject: H/22/93164 - 4 Station Road, Netley Abbey, SO31 5DT.

Revised drawings dated 25.01.2023. show the rear dormer with a pitched roof covered in natural slate. This is a definite improvement but still not a thing of great beauty, however it is probably as good as one can get in this situation.

The application form gives the wall material as brick which I rather doubt for the dormer given none of the walls are directly over any masonry below. What is envisaged for the cladding of the dormer? If it were natural slate it would fit in with the existing roofs at that level.

Subject to an acceptable answer to the above question my holding objection would then be withdrawn.

--

Tim J S Dyer, B.Sc.,Dip.Arch.(Birm), Grad.Dip.Conservation(AA), RIBA.
[Built Heritage Consultant.](#)