

900x250mm INSULATED SUPPLY DUCT
ENTERS BUILDING APPROX 3.15M AFFL.
DUCT RUNS IN COLD STORE CEILING VOID.

16000

3NO MITSUBISHI
PUHZ-ZRP250YKA3 AC
CONDENSERS TO SERVE AHU.
UNIT DIMENSIONS
1050x330x1338mm HIGH
UNIT WEIGHT 135kg
SOUND PRESSURE LEVEL 62dBA

700x700mm INSULATED SUPPLY
DUCT RISES TO HIGH LEVEL

CDU 001 DB REFER TO BOM-01
CDU 002 DB REFER TO BOM-01
CDU 003 DB REFER TO BOM-01

PLANT ENCLOSURE BY MAIN
CONTRACTOR

3000

750x750mm EXHAUST DUCT
TERMINATES WITH BIRDS BEAK
WITH MESH

750x750mm FRESH AIR INTAKE
DUCT TERMINATES WITH BIRDS
BEAK WITH MESH

AHU 001 DB
REFER TO BOM-01

1049

3329

750x750mm INSULATED EXTRACT
DUCT RISES TO HIGH LEVEL
(APPROX 4M TO UNDERSIDE)

750x750mm INSULATED EXTRACT
DUCT ENTERS BUILDING