

H/23/94758 – Tanera, Church Lane, Bursledon, SO31 8AB

Built Heritage Consultant Consultation Response received 17/03/2023

I have no problem with the revised fenestration and new door but not impressed with the new flue in lieu of the chimney. This will stand out like a sore thumb as one travels up Church Road.

If the existing external chimney base was extended upward to form a new chimney that would be acceptable and in keeping with the conservation area. On this item holding objection.