

G&M Technical Services
St Francis 66 St Johns Road
Hedge End Southampton SO30 4AG

CCW Ltd
Mr M Doe
Broadway Farm
Broad Oak
Botley
Southampton
SO302EU
Ref-GM 611-2023

28th February 2023

CCW – Rear Car Park Test Holes for Makeup Identification

Dear Maurice / Louisa

The following is as per your request to excavate 4 positions in the rear car park to analyse the ground makeup.

To cut 4 holes and dig up to identify the different materials used as follows.

1. Layer 1 80mm-100mm of 20mm base Tarmacadam.
2. Layer 2 200mm-300mm approximately of grasscrete concrete which has been compacted underneath the Tarmacadam.
3. A layer of Terram membrane. This acts as a ground support and a weed suppressant.

We hope the foregoing meets with your approval.

Yours sincerely

Tony Heathfield