

Arboricultural Documents

Report reference KTML36622 - AIA & AMS

Tree protection plan reference TPP 2022.05.02/04 Rev E

Comments

We are satisfied that the proposal can be achieved whilst retaining and protecting the significant trees on site. The submitted arboricultural information demonstrates this.

We raise no arboricultural objection to the proposal, subject to the following condition:

The development must accord with the arboricultural report reference KTML36622 - AIA & AMS. No excavation, demolition or development related works shall commence until the tree protection measures have been installed as per the tree protection plan reference TPP 2022.05.02/04 Rev E. Once installed, no access by vehicles or placement of goods, chemicals, fuels, soil or other materials shall take place within the protected area. Tree protection measures shall be retained in their approved form for the duration of the work and may only be modified subject to written agreement from the LPA. Reason - To retain and protect the existing trees which form an important part of the amenity of the locality.