

Altman, Rebecca

Subject: FW: Former Post Office - Conditions application ref. DC/22/94052; permission ref. F/20/89125 - Condition 11
Attachments: Quote TS-23-0338-C-Eastleigh Post Office - Privacy Screens (13.03.23).pdf

From: Lija Puncule <lija.puncule@hgp-architects.co.uk>
Sent: 04 April 2023 09:41
To: Altman, Rebecca <rebecca.altman@eastleigh.gov.uk>
Cc: Shane Knight <Shane.Knight@hgp-architects.co.uk>; Vivienne Conway <Vivienne.Conway@hgp-architects.co.uk>
Subject: Re: Former Post Office - Conditions application ref. DC/22/94052; permission ref. F/20/89125 - Condition 11

Hi Rebecca,

Apologies for the delay in getting back to you regarding Condition 11.

The lower part of the windows, shown in light grey, are translucent glass to allow the light in but not the views out.

The horizontal visual barrier louvres on north elevation of Building A are up to 1.6m height from finished floor level. The contractor has obtained a quote from Urban Skies, please see attached for your information.

Let me know if you require anything else.

Kind regards,

hgp

Lija Puncule
Architect