



Development Control Services
Eastleigh Borough Council
Eastleigh House
Upper Market Street
Eastleigh
Hampshire
SO50 9YN

Your ref
H/23/95025

Our ref
DSA000023437

Date
01/06/2023

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Partial garage conversion with cedar cladding and render to front elevation. Partial removal of existing rear extension to be replaced by rear canopy shade in cedar. Relocate front door with porch canopy. Carport & lower facias cedar clad to match, wood burner flue. To relocate stairwell. New first floor side window. Alterations to fenestration.

Site: H/23/95025: - 6 Clanfield Close, Chandler's Ford, Eastleigh, SO53 2HL.


Thank you for your letter dated 11/05/2023.

Please see the attached extract from Southern Water records showing the approximate position of surface water sewer within the development site. The exact position of the public asset must be determined on site by the applicant in consultation with Southern Water before the layout of the proposed development is finalized.

- The 225 mm public surface water sewer requires a clearance of 3 meters on either side of the sewer to protect it from construction works and to allow for future maintenance access.
- No development or tree planting should be carried out within 3 meters of the external edge of the sewer without consent from Southern Water.
- No soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 meters of a sewer.
- All existing infrastructure should be protected during the course of construction works.

Please refer to: southernwater.co.uk/media/3011/stand-off-distances.pdf

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.



Southern Water requires a formal application for a connection to the public sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service: developerservices.southernwater.co.uk and please read our New Connections Charging Arrangements documents which are available on our website via the following link: southernwater.co.uk/developing-building/connection-charging-arrangements

In situations where surface water is being considered for discharge to our network, we require the below hierarchy for surface water to be followed which is reflected in part H3 of the Building Regulations. Whilst reuse does not strictly form part of this hierarchy, Southern Water would encourage the consideration of reuse for new developments.

- Reuse
- Infiltration
- Watercourse
- Storm Sewer
- Combined Sewer

Guidance on Building Regulations is here:

gov.uk/government/publications/drainage-and-waste-disposal-approved-document-h

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development