

	Luminaire A	Luminaire B
Supplier	Ansell Lighting	D W Windsor
Type		Kirium Bulkhead -8 LED-2.7k-300 mA-6W-Frosted-Medium
Lamp(s)	AONIXLED/1	8 x 2.7k LED
Lamp Flux (klm)	1.97	0.78
Maintenance Factor	0.83	0.83
No. in Project	18	30



0514396389

DFL LIGHTING DESIGN/ELECTRICAL/MARTIN/ETC ENERGY REDUCTION/LIGHTING IMPACT	
PROJECT NAME: EAST HORTON BUSINESS PARK	
PROJECT No: 2888-DFL-ELG-XX-LD-EO-13001-S3	
SCALE: 1:500	DATE: 12 June 2023
CALCULATION: Horizontal Illuminance (lux)	
DESIGNER: DFL-UK (FE)	
-> Indicative light spill diagram -> Not for construction -> Initial light spill shown MF = 1.00 -> Modelling does not consider the blocking or shading effect of physical obstructions or site topography -> Indicative Light spill diagram must be read in conjunction with 2888-DFL-ELG-XX-RP-EO-13001-S3 Isolux contour shown: 5.0 Lux- Purple 0.4 Lux- Yellow 0.2 Lux- Blue Paper size scale 1-500@A2	
CHECKED BY: AR	APPROVED BY: AR
REVISION: P02	SUITABILITY: S3