

Morris, Rachael

From: Morris, Rachael
Sent: 15 June 2023 09:57
To: Morris, Rachael
Subject: FW: F/22/94174 Lapstone Playing Fields

From: Stringer, Chris <Chris.Stringer@eastleigh.gov.uk>
Sent: 15 June 2023 09:44
To: Morris, Rachael <Rachael.Morris@eastleigh.gov.uk>
Subject: RE: F/22/94174 Lapstone Playing Fields

Hi Rachael,

The updated report contains some more details on the supervision, so we can remove the second recommended condition as stated in my previous consultation response (dated 15th December 2022).

Therefore, we continue to raise no arboricultural objection, subject to the following compliance condition.

The development must accord with the arboricultural report reference HBD2202IAMS3. No excavation, demolition or development related works; no access by persons, vehicles or plant; and no placement of goods, chemicals, fuels, soil or other materials shall take place within the Root Protection Areas of any retained tree in proximity to the proposed culvert installation. Reason - To retain and protect the existing trees which form an important part of the amenity of the locality.

Kind regards,

Chris.

Chris Stringer
Tree Consultant
Countryside and Trees
Ext.: 8257
