

Additional Ecology response for H/23/94849 3 OAKFIELDS, EASTLEIGH, SO50 4RP
Retention of the garden room (Retrospective application)
Claire Campbell-Best

19/6/23

I have reviewed the site plans and additional information provided (email from Matthew Hammond 14 June 23). I am now satisfied that there are no further ecology or surface water drainage concerns. If the applicant would like to use a water butt for the roof drainage in addition, so that it can be used for watering the garden, this can be added to the existing downpipe with a downspout diverter so that any excess water then flows into the pond. The level of the outflow pipe must be checked so that if the pond fills up the water does not flow back towards the summerhouse.

Lisa Malter
Ecologist