



Development Control Services  
Eastleigh Borough Council  
Eastleigh House  
Upper Market Street  
Eastleigh  
Hampshire  
SO50 9YN

Your ref  
H/23/95385

Our ref  
DSA000024817

Date  
17/07/2023

Contact  
Tel 0330 303 0119

Dear Sir/Madam,

**Proposal:** Two storey side extension.

**Site:** H/23/95385: - Springfield, Rutland Gardens, Bursledon, Southampton, SO31 8FZ.

Thank you for your letter dated 26/06/2023.

Please see the attached extract from Southern Water records showing the approximate position of our existing public foul sewer within the development site. The exact position of the public assets must be determined on site by the applicant in consultation with Southern Water before the layout of the proposed development is finalised.

- The gravity sewer requires a clearance of 3 metres on either side of the gravity sewer to protect it from construction works and to allow for future maintenance access.
- No development or tree planting should be carried out within 3 metres of the external edge of the public gravity sewer without consent from Southern Water.
- No soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 metres of public or adoptable gravity sewers.
- All existing infrastructure should be protected during the course of construction works.

Please refer to: [southernwater.co.uk/media/3011/stand-off-distances.pdf](https://southernwater.co.uk/media/3011/stand-off-distances.pdf)

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.



Southern Water requires a formal application for any new connection to the public foul sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service: [developerservices.southernwater.co.uk](https://developerservices.southernwater.co.uk) and please read our New Connections Charging Arrangements documents which are available on our website via the following link: [southernwater.co.uk/developing-building/connection-charging-arrangements](https://southernwater.co.uk/developing-building/connection-charging-arrangements)

In situations where surface water is being considered for discharge to our network, we require the below hierarchy for surface water to be followed which is reflected in part H3 of the Building Regulations. Whilst reuse does not strictly form part of this hierarchy, Southern Water would encourage the consideration of reuse for new developments.

- Reuse
- Infiltration
- Watercourse
- Storm sewer
- Combined Sewer

Guidance on Building Regulations is here:  
[gov.uk/government/publications/drainage-and-waste-disposal-approved-document-h](https://gov.uk/government/publications/drainage-and-waste-disposal-approved-document-h)

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: [southernwater.co.uk](https://southernwater.co.uk) or by email at: [SouthernWaterPlanning@southernwater.co.uk](mailto:SouthernWaterPlanning@southernwater.co.uk)

Yours faithfully,

Future Growth Planning Team  
**Developer Services**

[southernwater.co.uk/developing-building/planning-your-development](https://southernwater.co.uk/developing-building/planning-your-development)