

Eastleigh Borough Council
Eastleigh House
Upper Market Street
Eastleigh
SO50 9YN

Hampshire 2050
The Castle
Winchester, Hampshire SO23 8UD

Telephone: 0300 555 1375
Fax: 01962 847055

www.hants.gov.uk

Enquiries To Matt Grantham

My reference 050248

Direct Line

Your reference F/22/94435

Date 17 July 2023

Email eastleighdc@hants.gov.uk

Dear Ms Sharpe,

MORTIMERS FARM, MORTIMERS LANE, FAIR OAK, EASTLEIGH, SO50 7EA

Alterations and extensions and conversion of 4 existing barns including Grade II listed Threshing Barn and Granary to create 4 dwellings, demolition of modern barn and construction of 5 new dwellings with associated gardens parking and car port/bat barn new sewerage treatment and new footpath on the southern side of Mortimers Lane

In regard to application F/22/94435, there is no objection to the proposals from a highways perspective, subject to conditions being applied as outlined below.

Following on from the previous HCC Highways consultation response dated 11 July 2023, where concerns were raised with the availability of space for the movement of a fire tender to access the southern end of the site, an updated vehicle tracking drawing has been received.

This drawing (5880/204 Rev A) now demonstrates that the movement is achievable and therefore there are no longer any concerns in this regard.

A request for updated refuse vehicle tracking was also made, however it is noted that the updates to the site layout shown in drawing 991-D-008 Rev B (superceding the previous revision A iteration) do not actually affect the layout within which a refuse vehicle will turn and access the bin collection point shown. As such, there is indeed no requirement for an updated Refuse vehicle track to be provided.

Director of Hampshire 2050
Garry Westbrook

ACCESS:

As outlined in previous consultation responses, CAD AutoTrack drawings have previously been received to demonstrate two-way movements at the existing access points taken from Mortimers Lane. These are acceptable and demonstrate that the movements are achievable without the potential need for a vehicle to have to wait on Mortimers Lane whilst another vehicle exists site.

In terms of pedestrian access, plans have now been submitted showing the proposed link from the development site to the existing footway network. This is accepted in principle, however a condition would be requested (should planning permission be granted) to ensure the footway is built prior to occupation of the site.

It should also be noted by the applicants that the footway (once approved) will need to be constructed via a S278 agreement for works on the highway, details of which can be found via the following link: <https://www.hants.gov.uk/transport/developers/section-278>

DEVELOPER CONTRIBUTIONS:

As outlined in the original consultation response, whilst no highway developer contributions are required, a contribution of £6K is requested for Traffic Regulation Orders (TRO's) associated with the development, is requested. This would primarily be for parking restrictions to prevent parking in the access junction and along the frontage on Mortimers Lane.

CONDITIONS:**CONSTRUCTION METHOD STATEMENT REQUIRED**

No development shall start on site until a construction method statement has been submitted to and approved in writing by the Planning Authority, which shall include:

- (a) A programme of and phasing of demolition (if any) and construction work;
- (b) The provision of long term facilities for contractor parking;
- (c) The arrangements for deliveries associated with all construction works;
- (d) Methods and phasing of construction works;
- (e) Access and egress for plant and machinery;
- (f) Protection of pedestrian routes during construction;
- (g) Location of temporary site buildings, compounds, construction material, and plant storage areas;
- (h) Details of the methodology for ensuring dirt is not transferred onto the highway from the site (i.e. wheel washers), and onwards mitigation should this fail, such as the employment of mechanical road sweepers.

Demolition and construction work shall only take place in accordance with the approved method statement.

Reason - In order that the Planning Authority can properly consider the effect of the works on the amenity of the locality.

Director of Hampshire 2050
Gary Westbrook

FOOTWAY CONSTRUCTION PROVISION

No occupation of the development shall start until the footway access providing a direct link between the site and Knowle Lane has been agreed in writing with the Local Planning Authority in conjunction with the Local Highway Authority, and has been constructed in accordance with approved plans.

Reason - To provide satisfactory access and in the interests of highway safety.

Yours sincerely,

Matt Grantham

Director of Hampshire 2050
Gary Westbrook