

Eastleigh Borough Council
Eastleigh House
Upper Market Street
Eastleigh
SO50 9YN

*Hampshire 2050
The Castle
Winchester, Hampshire SO23 8UD*

Telephone: 0300 555 1375
Fax: 01962 847055

www.hants.gov.uk

Enquiries To Matt Grantham

*My
reference* 050528

Direct Line

*Your
reference* A/23/95448

Date 8 August 2023

Email eastleighdc@hants.gov.uk

Dear Ms Morris,

MKM Building Supplies Eastleigh Ltd, Unit 5, Eastleigh, SO50 4DP

Illuminated and non illuminated fascia signs. Totem sign with top section illuminated only. (Retrospective application)

In regard to application A/23/95448, having reviewed the information contained within the application pack, whilst there would be no objection in principle to the application, additional information is requested.

The fascia signs are acceptable, however more detailed drawings of the positioning of the Totem Pole position are required as plans point to a generic location close to the site access/egress, and a site visit confirms the Totem is not already in place to assess (being a retrospective application).

Plans should clearly show the location and orientation of the sign, and this should be in a position where visibility splays to either the carriageway or adjacent foot/cycleway are not compromised - i.e. set back into site a minimum of 2.4m from the highway edge.

If updated plans can be provided, a reassessment can be undertaken accordingly.

Yours sincerely,

Matt Grantham

*Director of Hampshire 2050
Garry Westbrook*