

Eastleigh Borough Council
Eastleigh House
Upper Market Street
Eastleigh
SO50 9YN

Hampshire 2050
The Castle
Winchester, Hampshire SO23 8UD

Telephone: 0300 555 1375
Fax: 01962 847055

www.hants.gov.uk

Enquiries To Matt Grantham

My reference 050611

Direct Line

Your reference F/23/95549

Date 16 August 2023

Email eastleighdc@hants.gov.uk

Dear Mr Osmond,

BRIGHSTONE, BOTLEY ROAD, HORTON HEATH, EASTLEIGH, SO50 7DT

Construction of 5.no dwellings, landscaping, parking and associated works following demolition of existing dwelling, site clearance and preparation.

In regard to application F/23/95549, having reviewed the information contained within the application pack, there would be no objection in principle to the proposals, subject to clarification on points outlined below (access positioning and bin collection point), and conditions being applied as listed.

ACCESS:

At present, access into the site is from Botley Road, via a shared driveway access with the adjacent property to the north (Neerome), in the form of a dropped kerb vehicle crossover.

The proposals look to separate the access, providing a single access point for Neerome, and a new shared access point for the 5 proposed dwellings, again in the form of a drop kerb vehicle crossover.

Whilst the proposed drop kerb vehicle crossover is shown on plans, and has adequate visibility splays achievable and adequate geometry for two way vehicle movements, unfortunately plans do not show the existing drop kerb vehicle crossover for Neerome.

It is therefore requested that this is added to plans accordingly, so that the revised access can be checked for suitability, and also the extent of the drop kerb for both

Director of Hampshire 2050
Garry Westbrook

the new dwellings and Neerome can be fully assessed in combination. A single drop kerb vehicle crossover should not exceed 10.0m in length, and at present this measurement can not be undertaken, and onwards it may be that a central section between the two access points will need to have kerbs and the footway re-instated to full height.

ON-SITE LAYOUT:

Whilst it is understood that the internal site is not being put forward for adoption, an internal review has been undertaken for completeness.

Generally the site layout is acceptable and is not anticipated to have any issues that would onwards have an impact on the highway network, however it is noted from the vehicle tracking drawings supplied that a single vehicle track appears to take up more than half of the shared driveway width. Whilst low level, conflicting vehicle movements are likely to occur over time, with driving over landscaped areas the likely result. As such it is recommended that the developer completes two way tracking diagrams for the internal site layout in order to identify conflict areas, and onwards widens the driveway accordingly at these points.

Whilst the quantum of parking is for EBC to assess in their role as Local Parking Authority, in terms of layout, this is acceptable, with adequately sized parking bays and aisle widths suitable in size for turning to onwards allow for forward gear access and egress. It is noted however that parking bays located directly adjacent to landscaping are of standard width, and it would be recommended that these are widened by 0.3m (per affected side) to ensure people can step in and out of the vehicles onto a hardstanding area rather than turn the grass (for instance) into mud over time.

Additionally, some elements of parking are potentially not in the most convenient location for the users, and so may be disregarded for more informal parking options. The main location is in regard to parking for plot 2, where the parking is to the rear of the rear garden, and it may be that residents choose to park informally at the front for convenience. It may be worth investigating whether at least one space could be located to the side of the plot (parallel bay) via landscaping conversion to assist in preventing this happening. This is not however an objectionable point.

In terms of emergency vehicle access, this is acceptable, with adequate space afforded for the largest vehicle anticipated on site - fire tender - as demonstrated in the submitted tracking drawings.

SERVICING:

It is outlined that servicing will be via roadside collection, and the residents will need to pull their bins close to kerbside on collection days. Given there are 5 dwellings proposed, there is the potential for these bins to become obstructive to driveway access, visibility and footways. As such, it would be requested that a bin collection

Director of Hampshire 2050
Gary Westbrook

point is provided and added to plans for assessment. EBC Direct Services should also be consulted in regard to the collection to ensure they are happy with the arrangements being put forward.

CONDITIONS:

CONSTRUCTION METHOD STATEMENT REQUIRED

No development shall start on site until a construction method statement has been submitted to and approved in writing by the Planning Authority, which shall include:

- (a) A programme of and phasing of demolition (if any) and construction work;
- (b) The provision of long term facilities for contractor parking;
- (c) The arrangements for deliveries associated with all construction works;
- (d) Methods and phasing of construction works;
- (e) Access and egress for plant and machinery;
- (f) Protection of pedestrian routes during construction;
- (g) Location of temporary site buildings, compounds, construction material, and plant storage areas;
- (h) Details of the methodology for ensuring dirt is not transferred onto the highway from the site (i.e. wheel washers), and onwards mitigation should this fail, such as the employment of mechanical road sweepers, and the subsequent refresh of street lining (as and when required) should this be damaged during the process.

Demolition and construction work shall only take place in accordance with the approved method statement.

Reason - In order that the Planning Authority can properly consider the effect of the works on the amenity of the locality.

ACCESS CONSTRUCTION PROVISION

No development shall start on site until the access, including the footway and/or verge crossing shall be constructed and lines of sight of 2.0 metres by 43.0 metres provided in accordance with the approved plans. The lines of sight splays shown on the approved plans shall be kept free of any obstruction exceeding 0.6 metre in height above the adjacent carriageway and shall be subsequently maintained so thereafter.

Reason - To provide satisfactory access and in the interests of highway safety.

CLOSURE OF EXISTING ACCESS PROVISION

Before use of the development is commenced the sections of redundant existing access(es) from the site to Botley Road shall be permanently stopped up and effectively closed with the footway provided or verge reinstated, in accordance with details which have been submitted to and approved by the Planning Authority.

Reason - In the interests of highway safety.

BIN/CYCLE STORE - DETAILS REQUIRED

No development shall start on site until plans and particulars showing details of the provisions of a bin collection point within the site have been submitted and approved in

Director of Hampshire 2050
Gary Westbrook

writing by the Planning Authority. The development shall be carried out in accordance with the approved details before the use of the development is commenced and shall be retained thereafter.

Reason - To ensure adequate provision within the site.

Yours sincerely,

Matt Grantham

Director of Hampshire 2050
Gary Westbrook