



Hampshire County Council

Universal Services
The Castle
Winchester, Hampshire SO23 8UD

Tel: 0300 555 1375
Fax 01962 847055
www.hants.gov.uk

Enquiries to	Susanna Hope	My reference	SWM/2023/0434
Direct Line	0370 779 8679	Your reference	F/23/95574
Date	11 September 2023	Email	swm.consultee@hants.gov.uk

Dear Sir/Madam,

Construction of 12no. dwellings comprising of 9no. apartments and 3no. houses, with associated landscaping, parking, and access from Derby Road. at 237 Chamberlayne Road and 5b Derby Road, Eastleigh, SO50 5HX(Application No. F/23/95574

Hampshire County Council as Lead Local Flood Authority has provided comments in relation to the above application in our role as statutory consultee on surface water drainage for major developments.

This response does not reflect the position of Hampshire County Council as the Highway Authority. If there is a potential for the drainage features to be offered for adoption, this will need to be discussed separately with Highways development planning as they might not be considered acceptable by the Highway Authority.

In order to assist applicants in providing the correct information to their Local Planning Authority for planning permission, Hampshire County Council has set out the information it requires to provide a substantive response at <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning>

The County Council has reviewed the following documents relating to the above application:

- **Email from Mark Dewson (Reuby and Stagg) to Susanna Hope (Hampshire County Council)/ RE: 237 Chamberlayne Road and 5b Derby Road application ref. F/23/95574/ Dated 07/09/2023 3:58pm.**

Director of Universal Services
Patrick Blogg

Thank you for confirming that the surface water drainage model was run with the entire site being impermeable. As such, the urban creep allowance has already been built in.

Thank you for confirming that if the pipe is in too poor a condition to be repaired that it will be replaced. We understand from our phone call that under no circumstances is this anticipated to be unachievable. Thank you for this confirmation as the only other surface water sewer near the site would necessitate a site layout change to connect to and a foul sewer connection is not deemed a suitable alternative.

We are satisfied with the principles of the development and have no objection but recommend that the following conditions are applied to this application.

1. No development shall begin until a detailed surface water drainage scheme for the site, based on the principles within the Reuby and Stagg Flood Risk Assessment and Drainage Strategy ref: 10583/June 2023, has been submitted and approved in writing by the Local Planning Authority. The submitted details should include:

- a. A technical summary highlighting any changes to the design from that within the approved Flood Risk Assessment.
- b. Detailed drainage plans to include type, layout and dimensions of drainage features including references to link to the drainage calculations. This should include confirmation of the condition of any existing drainage being reused or connected to.
- c. Detailed drainage calculations to demonstrate existing runoff rates are not exceeded and there is sufficient attenuation for storm events up to and including 1:100 + climate change.
- d. Evidence that urban creep has been included within the calculations.
- e. Confirmation that sufficient water quality measures have been included to satisfy the methodology in the Ciria SuDS Manual C753.
- f. Exceedance plans demonstrating the flow paths and areas of ponding in the event of blockages or storms exceeding design criteria.
- g. Details for the long-term maintenance arrangements for the surface water drainage system shall be submitted to and approved in writing by the Local Planning Authority prior to the first occupation of any of the dwellings. The submitted details shall include maintenance schedules for each drainage feature type and ownership and details of protection measures.

As a statutory consultee, the County Council has a duty to respond to consultations within **21 days**. The 21-day period will not begin until we have received sufficient information to enable us to provide a meaningful response.

Please ensure all data is sent to us via the relevant Local Planning Authority.

If you require additional guidance on providing the correct information, we recommend you use our **Surface Water Management Pre-application service** which will enable discussions with the reviewing engineer and scope out works that would address the points raised. For full details, please visit:

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning> and click on [pre-application advice request form](#).

This response has been provided using the best knowledge and information submitted by the applicant as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,



Flood and Water Management Team
Economy, Transport & Environment Department,
Hampshire County Council, 1st Floor, Ell Court West,
The Castle, Winchester, Hampshire SO23 8UD

Web:

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding>

General guidance for the application

It is important to ensure that the long-term maintenance and responsibility for Sustainable Drainage Systems is agreed between the Local Planning Authority and the applicant before planning permission is granted. This should involve discussions with those adopting and/or maintaining the proposed systems, which could include the Highway Authority, Planning Authority, Parish Councils, Water Companies and private management companies.

For SuDS systems to be adopted by Hampshire Highways it is recommended that you visit the website at:

<https://www.hants.gov.uk/transport/developers/constructionstandards> for guidance on which drainage features would be suitable for adoption.

Where the proposals are connecting to an existing drainage system it is likely that the authorities responsible for maintaining those systems will have their own design requirements. These requirements will need to be reviewed and agreed as part of any surface water drainage scheme.

Works in relation to ordinary watercourses

*PLEASE NOTE: If the proposals include works to an ordinary watercourse, under the Land Drainage Act 1991, as amended by the Flood and Water Management Act 2010, prior consent from the Lead Local Flood Authority is required. **This consent is required as a separate permission to planning.***

Information on ordinary watercourse consenting can be found at the following link

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/c/hangewatercourse>

It is strongly recommended that this information is reviewed before Land Drainage consent application is made.

*For guidance on providing the correct information, we recommend you use our **Ordinary Watercourse Consents Pre-application service** and help avoid delays occurring at the formal application stage. A Pre-application service for Ordinary Watercourse Consents is available, allowing consents to go through in a smoother, often more timely manner. For full information please visit:*

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/c/hangewatercourse>