

MR CHRIS SHIPPERLEY
ANDERS ROBERTS & ASSOCIATES
CHAPEL STUDIOS
14 PUREWELL
CHRISTCHURCH
BH23 1EP

Application	F/23/95753
Please ask for	Rachael Morris
Direct dial	023 8068 8463
Working hours	Mon to Fri 8:30am to 5pm
Email	rachael.morris@eastleigh.gov.uk

Friday 8 December 2023

Town and Country Planning Act 1990
The Town and Country Planning (Development Management Procedure) (England)
Order 2015

Application No. F/23/95753

In pursuance of their powers under the above Act and in accordance with your application received on Friday 28 July 2023 the Council, as Local Planning Authority hereby **Permit** the following :

Description: Erection of 1.no 3-bedroom bungalow with associated parking following the demolition of existing garages and severing of land
Site: 5-7 ALLINGTON LANE, FAIR OAK, EASTLEIGH, SO50 7DA

Subject to due compliance with the following conditions:

- 1 The development hereby permitted shall be implemented in accordance with the following plans numbered: FB8570/100 Rev A, FB8570/101, FB8570/102 Rev A
Reason: For the avoidance of doubt and in the interests of proper planning.
- 2 The development hereby permitted shall start no later than three years from the date of this decision.
Reason: To comply with Section 91 of the Town and Country Planning Act 1990
- 3 No development shall commence on site until a Construction Environmental Method Plan (CEMP) has been submitted to and approved in writing by the Local Planning Authority, which shall include: a) A programme of and phasing of demolition (if any) and construction work;

- b) Provision of long term facilities for contractor parking and parking of vehicles of site operatives and visitors;
- c) Access and egress for plant and machinery;
- d) Location of temporary site buildings, compounds, construction material, and plant storage areas used during demolition and construction;
- e) The arrangements for deliveries associated with all construction works, loading/ unloading of plant & materials and restoration of any damage to the highway [including vehicle crossovers and grass verges]
- f) The arrangements for the routing/ turning of lorries and details for construction traffic access to the site;
- g) A scheme for controlling noise and vibration from demolition and construction activities (to include piling);
- h) Provision for storage, collection, and disposal of rubbish from the development during construction period;
- i) Details of the methodology for ensuring dirt is not transferred onto the highway from the site (i.e wheel washers), and onwards mitigation should this fail, such as the employment of mechanical road sweepers, and the subsequent refresh of street lining (as and when required) should this be damaged during the process;
- j) The erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate;
- k) Details of any temporary lighting to be designed in accordance with best practice;
- l) Methods and phasing of construction works;
- m) Protection of pedestrian routes during construction;
- n) how complaints about harm or adverse impact to amenity will be received and considered.

Demolition and construction work shall only take place in accordance with the approved method statement.

Reason: In order that the Planning Authority can properly consider the effect of the works on the amenity of the locality.

- 4 Prior to the commencement of development, details of the proposed means of foul sewerage and surface water disposal shall be submitted to, and approved in writing by, the Local Planning Authority, in consultation with Southern Water. This shall be in broad accordance with the submitted Surface Water Plan (FB8570/102 Rev A)
Reason: To ensure satisfactory provision of foul and surface water drainage.
- 5 The development must accord with the arboricultural report reference TR.V1.5-7.AL.FO.E. No excavation, demolition or development related works shall commence until the tree protection measures have been installed as per the tree protection plan contained within the report. Once installed, no access by vehicles or placement of goods, chemicals, fuels, soil or other materials shall

take place within the protected area. Tree protection measures shall be retained in their approved form for the duration of the work and may only be modified subject to written agreement from the LPA.

Reason: To retain and protect the existing trees which form an important part of the amenity of the locality.

- 6 A watching brief should be followed at all times during construction works and confirmation of this shall be submitted to by the Local Planning Authority (LPA) prior to completion. In the event that previously unidentified contamination is found during the watching brief it must be immediately reported to the Local Planning Authority. Work shall then cease until an investigation and risk assessment, and where required a remediation scheme, has been submitted to and approved in writing by the Local Planning Authority. Where a remediation scheme is required by the Local Planning Authority, the development shall not be brought into use until a verification report for the remediation work has been submitted to and approved in writing by the Local Planning Authority. All works shall be undertaken by a competent person in accordance with best practice as outlined in BS10175:2011 and CLR11. Any gas monitoring deemed appropriate is to be in accordance with best practice as outlined in such documents as BS8576:2013, BS 8485:2015, Claire RB17 and CIRIA C665.
Reason: To minimise the risk from land contamination for the safety of the property's occupiers.
- 7 Prior to first use, any imported soils required for the development hereby permitted shall be demonstrated to be suitable for its intended end use and meet the approval of the Local Planning Authority.
Reason: To minimise the risk from land contamination for the safety of the future occupiers of the development.
- 8 Prior to the first occupation of the approved dwelling, supporting information to confirm the predicted internal mains water consumption will achieve a maximum level of 110 litres/person/day shall be submitted to and approved in writing by the Local Planning Authority. The development shall not be carried out otherwise than in accordance with the approved details.
Reason: To support a comprehensive approach to high quality design across the site and to achieve water efficiency.
- 9 The development hereby permitted shall not be occupied until a mitigation package addressing the additional nutrient inputs arising from the development has been submitted to, and approved in writing by, the Local Planning Authority. Such a mitigation package shall address all of the additional nutrient loading upon protected European sites from the development and shall allow the Local Planning Authority to ascertain on the basis of the best available scientific evidence that such additional nutrient loading will not have an adverse effect on

the integrity of those European Sites, having regard to the conservation objectives for they are designated. The mitigation package shall be implemented in full and evidence of this provided to the Local Planning Authority in writing prior to first occupation of the development.

Reason: To mitigate the nitrates impacts arising from the development upon the European protected Solent Complex in accordance with the requirements of the Conservation of Habitats and Species Regulations 2017.

- 10 Prior to the occupation of any dwelling hereby approved, evidence that the dwelling complies with Part M4(2) standard (Accessible and adaptable dwellings) of the building regulations for new build residential development (or future equivalent), shall be submitted to and approved in writing by the Local Planning Authority. The development shall not be carried out otherwise than in accordance with the approved details.
Reason: To ensure the development meets higher national access standards in accordance with policy DM29 of the Eastleigh Borough Local Plan 2016-2036.
- 11 Prior to first occupation a landscaping scheme shall be submitted to and approved in writing by the Local Planning Authority. The scheme shall cover all hard and soft landscaping (including boundary treatments) and shall provide details of timings for all landscaping and any future maintenance. The works shall be carried out in accordance with the approved plans and to the appropriate British Standard and maintained thereafter.
Reason: In the interests of the visual amenity of the locality and to safeguard the amenities of neighbouring residents
- 12 Prior to first occupation, the vehicle parking as shown on plans referenced FB8570/100 Rev A shall be implemented and thereafter retained for the lifetime of the development.
Reason: To make provision for off street parking for the purpose of highway safety
- 13 Prior to first occupation, details of the bin storage shall be submitted to and approved in writing by the Local Planning Authority. The agreed details shall then be implemented in full within 1 month of occupation and retained for the lifetime of the development.
Reason: To make provision for off street parking for the purpose of highway safety.
- 14 The submitted Preliminary Ecological Appraisal Report (referenced PEAR.V2.5-7.AL.FO.E V1) shall be adhered to in full, including all recommendations in section 5.
Reason: To ensure a biodiversity enhancement in accordance with Policy DM11 from the Eastleigh Borough Local Plan (2016-2036)

- 15 No burning of materials obtained by site clearance, or any other source shall take place during the demolition, construction and fitting out process.
Reason: To protect the amenities of the occupiers of nearby properties.
- 16 No construction, demolition or deliveries to the site shall take place during the demolition and construction period except between the hours of 0800 to 1800 Mondays to Fridays or 0900 to 1300 on Saturdays and not at all on Sundays or Bank Holidays.
Reason: To protect the amenities of the occupiers of nearby dwellings.
- 17 Notwithstanding the provisions of the Town and Country Planning [General Permitted Development] Order 2015 [or any order revoking and re-enacting that Order with or without modification], no development permitted by Classes AA, B and C, of Part 1 of Schedule 2 of the order shall be carried out without the prior written consent of The Local Planning Authority.
Reason: To protect the amenities of the locality and to maintain a good quality environment.

Note to Applicant: Any new closed board fencing should have hedgehog holes (15 x 15 cm minimum) cut into the base boards to allow free passage of small mammals through the gardens.

Note to Applicant: Vegetation clearance and existing outbuilding demolition shall be undertaken outside the bird nesting season (ie between Sept-end Feb) unless otherwise thoroughly checked by a qualified ecologist. If there are any active nests, a 5 m buffer shall be erected to protect the nest from disturbance until the young have fledged and left the nest.

Note to Applicant: The development could be impacted by radon and you are advised to consult the radon UK map at (UKradon - UK maps of radon). If the radon risk is greater than 1% radon protection should be considered for the new development. If greater than 3% risk then radon protection will need to be provided in accordance with Building Regulations, with basic protection required at 3-10% and full protection above 10%.

Note to Applicant: In accordance with paragraph 38 of the National Planning Policy Framework (Sept 2023), Eastleigh Borough Council takes a positive approach to the handling of development proposals so as to achieve, whenever possible, a positive outcome and to ensure all proposals are dealt with in a timely manner.

Yours faithfully

A handwritten signature in black ink that reads "N Parker". The signature is written in a cursive style with a horizontal line underneath the name.

Nicholas Parker
Planning Manager

N.B. See Attached Notes