

Ecology response for DC/23/96558 259 WINCHESTER ROAD, CHANDLER'S FORD, EASTLEIGH,
SO53 2DX

Discharge of condition 7 (sustainable drainage) and 8 (Part M4(2) building regulations) from
F/22/92694 for the Erection of a 1no. five-bedroom detached dwelling with detached garage

Rachael Morris

20/12/23

I have reviewed the sustainable drainage information and am satisfied that permeable paving and
soakaways are acceptable on this site. The location of the soakaway and use of permeable paving
must be shown on the proposed site plan before condition 7 can be discharged.

Lisa Malter

Ecologist