

Additional Ecology response 20 12 23 for DC/23/95471 Land North West of Winchester Road, Boorley Green, Hampshire, SO32 2BX,

Discharge of conditions application following outline planning permission O/15/75953, as amended by X/19/84943 for condition 11 (Surface Water Drainage) for Boorley Gardens part of Phase 3E and part of Phase 3F

Please comment on the additional/amended information submitted in November 2023

Liz Harrison

20/12/23

I have reviewed the updated condition 11 Drainage Maintenance Management Plan (November 2023), and the Phase 3 Drainage Statement (Issue 3 November 2023). On the Exceedance flow routes (Rev D, sheet 1 of 2) there is a place where 2 flow arrows appear to converge (circled in red), which does not make sense to me.



On sheet 2 of 2 one of the exceedance flow route arrows appears to flow from the car park into the garden of plot number 662, and possibly also into the garden of plot 661. I don't think this is acceptable. Exceedance flows should run along the roadways and off site, but not onto the properties.



Please could you ask for an explanation?

Lisa Malter

