

Tumu Consulting		Page 1
20 East Sands Burbage Marlborough Wiltshire SN8 3AN	Ageas Bowl Southampton Character Area 4	
Date 01/08/2022 File 19320 CHARACTER AREA 4 PCP.SRCX	Designed by JE Checked by AC	
Micro Drainage		Source Control 2018.1

Summary of Results for 100 year Return Period (+40%)

Half Drain Time : 803 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Control (l/s)	Max Σ Outflow (l/s)	Max Volume (m³)	Status
15 min Summer	53.931	0.281	0.0	2.0	2.0	63.3	O K
30 min Summer	54.031	0.381	0.0	2.0	2.0	85.8	O K
60 min Summer	54.137	0.487	0.0	2.0	2.0	109.6	O K
120 min Summer	54.241	0.591	0.0	2.0	2.0	133.1	O K
180 min Summer	54.294	0.644	0.0	2.0	2.0	144.8	O K
240 min Summer	54.323	0.673	0.0	2.0	2.0	151.3	O K
360 min Summer	54.357	0.707	0.0	2.0	2.0	159.1	O K
480 min Summer	54.371	0.721	0.0	2.0	2.0	162.3	O K
600 min Summer	54.374	0.724	0.0	2.0	2.0	162.9	O K
720 min Summer	54.370	0.720	0.0	2.0	2.0	162.0	O K
960 min Summer	54.359	0.709	0.0	2.0	2.0	159.6	O K
1440 min Summer	54.330	0.680	0.0	2.0	2.0	153.1	O K
2160 min Summer	54.279	0.629	0.0	2.0	2.0	141.6	O K
2880 min Summer	54.225	0.575	0.0	2.0	2.0	129.4	O K
4320 min Summer	54.105	0.455	0.0	2.0	2.0	102.3	O K
5760 min Summer	54.008	0.358	0.0	2.0	2.0	80.5	O K
7200 min Summer	53.932	0.282	0.0	2.0	2.0	63.5	O K
8640 min Summer	53.875	0.225	0.0	2.0	2.0	50.7	O K
10080 min Summer	53.834	0.184	0.0	1.9	1.9	41.3	O K
15 min Winter	53.968	0.318	0.0	2.0	2.0	71.5	O K
30 min Winter	54.081	0.431	0.0	2.0	2.0	96.9	O K
60 min Winter	54.201	0.551	0.0	2.0	2.0	123.9	O K
120 min Winter	54.318	0.668	0.0	2.0	2.0	150.3	O K
180 min Winter	54.378	0.728	0.0	2.0	2.0	163.8	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)
15 min Summer	130.405	0.0	61.2	26
30 min Summer	87.611	0.0	84.5	41
60 min Summer	56.129	0.0	111.7	70
120 min Summer	34.675	0.0	139.5	128
180 min Summer	25.749	0.0	155.9	188
240 min Summer	20.687	0.0	167.4	246
360 min Summer	15.234	0.0	185.3	364
480 min Summer	12.237	0.0	198.7	482
600 min Summer	10.316	0.0	209.4	600
720 min Summer	8.967	0.0	218.4	676
960 min Summer	7.182	0.0	232.9	788
1440 min Summer	5.242	0.0	253.1	1044
2160 min Summer	3.818	0.0	280.7	1460
2880 min Summer	3.045	0.0	297.9	1880
4320 min Summer	2.209	0.0	322.6	2640
5760 min Summer	1.757	0.0	341.5	3352
7200 min Summer	1.472	0.0	356.0	4040
8640 min Summer	1.274	0.0	368.1	4752
10080 min Summer	1.128	0.0	378.2	5440
15 min Winter	130.405	0.0	69.3	26
30 min Winter	87.611	0.0	95.3	40
60 min Winter	56.129	0.0	125.9	70
120 min Winter	34.675	0.0	156.9	126
180 min Winter	25.749	0.0	175.4	184

Tumu Consulting		Page 2
20 East Sands Burbage Marlborough Wiltshire SN8 3AN	Ageas Bowl Southampton Character Area 4	
Date 01/08/2022 File 19320 CHARACTER AREA 4 PCP.SRCX	Designed by JE Checked by AC	
Micro Drainage		Source Control 2018.1

Summary of Results for 100 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Control (l/s)	Max E Outflow (l/s)	Max Volume (m³)	Status
240 min Winter	54.412	0.762	0.0	2.0	2.0	171.5	O K
360 min Winter	54.455	0.805	0.0	2.0	2.0	181.1	O K
480 min Winter	54.475	0.825	0.0	2.0	2.0	185.6	O K
600 min Winter	54.482	0.832	0.0	2.0	2.0	187.2	O K
720 min Winter	54.481	0.831	0.0	2.0	2.0	187.0	O K
960 min Winter	54.466	0.816	0.0	2.0	2.0	183.6	O K
1440 min Winter	54.427	0.777	0.0	2.0	2.0	174.9	O K
2160 min Winter	54.356	0.706	0.0	2.0	2.0	158.9	O K
2880 min Winter	54.278	0.628	0.0	2.0	2.0	141.2	O K
4320 min Winter	54.093	0.443	0.0	2.0	2.0	99.7	O K
5760 min Winter	53.952	0.302	0.0	2.0	2.0	67.9	O K
7200 min Winter	53.857	0.207	0.0	2.0	2.0	46.6	O K
8640 min Winter	53.799	0.149	0.0	1.9	1.9	33.6	O K
10080 min Winter	53.764	0.114	0.0	1.8	1.8	25.8	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)
240 min Winter	20.687	0.0	188.2	242
360 min Winter	15.234	0.0	208.3	358
480 min Winter	12.237	0.0	223.2	470
600 min Winter	10.316	0.0	235.2	582
720 min Winter	8.967	0.0	245.1	690
960 min Winter	7.182	0.0	261.0	892
1440 min Winter	5.242	0.0	280.4	1112
2160 min Winter	3.818	0.0	315.5	1580
2880 min Winter	3.045	0.0	334.9	2044
4320 min Winter	2.209	0.0	362.9	2816
5760 min Winter	1.757	0.0	384.4	3520
7200 min Winter	1.472	0.0	400.8	4176
8640 min Winter	1.274	0.0	414.7	4760
10080 min Winter	1.128	0.0	426.4	5352

Tumu Consulting		Page 3
20 East Sands Burbage Marlborough Wiltshire SN8 3AN	Ageas Bowl Southampton Character Area 4	
Date 01/08/2022 File 19320 CHARACTER AREA 4 PCP.SRCX	Designed by JE Checked by AC	
Micro Drainage		Source Control 2018.1

Rainfall Details

Rainfall Model	FSR	Winter Storms	Yes
Return Period (years)	100	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	19.800	Shortest Storm (mins)	15
Ratio R	0.350	Longest Storm (mins)	10080
Summer Storms	Yes	Climate Change %	+40

Time Area Diagram

Total Area (ha) 0.282

Time (mins)	Area	Time (mins)	Area	Time (mins)	Area
From:	To:	(ha)	From:	To:	(ha)
0	4	0.094	4	8	0.094
				8	12
					0.094

Tumu Consulting		Page 4
20 East Sands	Ageas Bowl	
Burbage Marlborough	Southampton	
Wiltshire SN8 3AN	Character Area 4	
Date 01/08/2022	Designed by JE	
File 19320 CHARACTER AREA 4 PCP.SRCX	Checked by AC	
Micro Drainage	Source Control 2018.1	

Model Details

Storage is Online Cover Level (m) 54.500

Porous Car Park Structure

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	15.0
Membrane Percolation (mm/hr)	1000	Length (m)	50.0
Max Percolation (l/s)	208.3	Slope (1:X)	0.0
Safety Factor	1.5	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	53.650	Membrane Depth (m)	0

Hydro-Brake® Optimum Outflow Control

Unit Reference	MD-SHE-0069-2000-0850-2000
Design Head (m)	0.850
Design Flow (l/s)	2.0
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	69
Invert Level (m)	53.660
Minimum Outlet Pipe Diameter (mm)	100
Suggested Manhole Diameter (mm)	1200

Control Points	Head (m)	Flow (l/s)	Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	0.850	2.0	Kick-Flo®	0.535	1.6
Flush-Flo™	0.257	2.0	Mean Flow over Head Range	-	1.8

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	1.7	0.800	1.9	2.000	3.0	4.000	4.1	7.000	5.3
0.200	2.0	1.000	2.2	2.200	3.1	4.500	4.3	7.500	5.5
0.300	2.0	1.200	2.3	2.400	3.2	5.000	4.5	8.000	5.7
0.400	1.9	1.400	2.5	2.600	3.3	5.500	4.7	8.500	5.8
0.500	1.7	1.600	2.7	3.000	3.6	6.000	4.9	9.000	6.0
0.600	1.7	1.800	2.8	3.500	3.8	6.500	5.1	9.500	6.1