

Michael Istratoglou - 50 Chestnut Avenue, Eastleigh, SO50 5AL

MCS 020(a) - Heat Pump Sound Calculator

Assessment Details

Heat pump model is EDLA06E2V3 and it is 3.3 metres from the assessment window.

There are 2 reflecting surfaces including the floor and it is partially seen.

The assessment position is one metre perpendicular to the centre of the closest habitable room.

Step	Instructions	MCS contractor results/notes
1	Assessment Date	02/03/2026
2	Assessment Position	Ground floor doors at 52 Chestnut Avenue
3	A-weighted sound power level of the heat pump dBA	60.0
4a	Determine the directivity 'Q' of the heat pump noise.	Q4
4b	Measure the distance from the heat pump to the assessment position in metres	3.3
5	Determination of barrier correction - select barrier type	Solid Wall
6	Determination of barrier correction - select line of sight	Partially seen
7	Calculate Sound Pressure Level	39.7
8	Final Result?	Fail

Final Sound Pressure Level: 39.7 dB(A) - NON-COMPLIANT

This assessment follows the MCS 020 planning standard for heat pumps.
Maximum permitted sound level at assessment position: 37 dB(A)

Annotated Planning Application Photo

