

Altman, Rebecca

Subject: FW: LLFA likely response RM apps The Folds, Holme and Homestall

Sent: 23 April 2026 11:43

Hi all,

Following our meeting with Sarah Reghif this morning, we can confirm that the garden areas shown within the developed area on drawing 332612639-STN-17-XX-DR-C-0513 have not been included within the modelled areas.

The surface water catchment area drawings for the Folds parcel (Ref: 332612639-STN-17-XX-DR-C-0507-0512), the Holme parcel (Ref: 332612639-STN-13-XX-DR-C-0504-0506) and the Homestall parcel (Ref: 332612639-STN-14-XX-DR-C-0504-0506) show the areas included within the modelling. The permeable garden areas are allowed to continue to discharge at greenfield rate.

Kind Regards

Amy Bartholomew BEng (Hons), CEng MICE
Associate Civil Engineer

Direct: +44 118 952 3172
amy.bartholomew@stantec.com

Stantec UK Limited



With every community, we redefine what's possible.

The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately. For a list of Stantec's operating entities with associated license and registration information, please visit [stantec.com](https://www.stantec.com).
land as registration number 01188070.