

H/26/101294 – 15 HAZEL CLOSE, CHANDLER'S FORD

06/05/2026

Dear Gina,

We have no objections regarding the front porch – there are no significant trees in close proximity.

Regarding the rear extension, there are several protected trees in relatively close proximity to the proposed development. Therefore, we would request a Tree Protection Plan, pre-commencement, demonstrating how the trees are to be protected and retained.

Therefore, we raise no arboricultural objection to the proposal, subject to the following condition:

No excavation, demolition or development related works shall take place on site until a scaled and referenced tree protection plan, as per British Standard 5837:2012 (Trees in Relation to Design, Demolition and Construction – Recommendations), is submitted and approved by the LPA. The approved tree protection plan must be adhered to in full, and may only be modified subject to written agreement from the LPA. Reason: to retain and protect the existing trees which form an important part of the amenity of the locality.