

F/26/101495 - MONKS BROOK, 19 HURSLEY ROAD, CHANDLER'S FORD

22/06/2026

Dear Rebecca,

Regarding the location of the TV and supporting structure, we have no arboricultural objection.

I did not see any information on power/signal supply, but it is pretty easy to avoid root protection areas given the space in the garden.

If you are minded to approve the application, please condition the following:

No excavation related work, shall take place within the calculated Root Protection Area – defined as a distance of 12 times the diameter of the stem (as measured at 1.5 m above ground level) – of any tree with a stem greater than 75 mm diameter (as measured at 1.5 m above ground level). Reason: to retain and protect the existing trees which form an important part of the amenity of the locality.