

Installation Type	Unit of Measure	Capacity/Flow rate (1)	Use Factor (2)	Fixed use (litres/person/day) (3)	Litres/person/day = [(1)x(2)] + (3) (4)
WC (single flush)	Flush Volume (litres)		4.42	0.00	0
WC (dual flush)	Full flush Volume (litres)	6	1.46	0.00	8.76
	Part flush Volume (litres)	3	2.96	0.00	8.88
WC (multiple fittings)	Average effective flushing Volume (litres)		4.42	0.00	0
Taps (excluding kitchen/utility room taps)	Flow rate (litres/min)	6.00	1.58	1.58	11.06
Bath (where shower also present)	Capacity to overflow(litres)	173.00	0.11	0.00	19.03
Shower (where bath also present)	Flow Rate(litres / minute)	6.00	4.37	0.00	26.22
Bath Only	Capacity to overflow(litres)		0.50	0.00	0
Shower Only	Flow Rate (litres/minute)		5.60	0.00	0
Kitchen/Utility room sink taps	Flow rate (litres/minute)	9.00	0.44	10.36	14.32
Washing Machine	(Litres/kg dry load)	8.17	2.1	0.00	17.157
Dishwasher	(Litres/place setting)	1.25	3.6	0.00	4.5
Waste disposal unit	(Litres/use)	☐ Present	3.08	0.00	0
Water Softener	(Litres/person/day)		1.00	0.00	0
	(5)	Total Calculated use (litres/person/day) =SUM(column 4)			109.93
	(6)	Contribution from greywater (litres/person/day)			0
	(7)	Contribution from rainwater (litres/person/day)			0
	(8)	Normalisation factor			0.91
	(9)	Total internal water consumption = [(5)-(6)-(7)]x(8) (litres/person/day)			100.03
	(10)	External water use			5.0
	(11)	Total water consumption (Building Regulation 17.K) =(9)+(10)(litres/person/day)			105.0

Installation Type	Make/Model (mandatory)	Litres/Person/Day
WC (dual flush)	Grohe Bau Rimless Close Coupled Toilet	17.64
Taps	Grohe Start Edge Mono Basin Mixer	11.06
Baths (shower(s) present)	Ideal Standard Tesi	19.03
Showers (bath(s) present)	Triton T80Z 8.5Kw Fast Fit Eco Electric shower	26.22
Kitchen Taps	Grohe Ambi Kitchen Tap	14.32
Washing Machines		17.157
Dishwasher		4.5



©Water Research Centre Limited 2026

[Terms and Conditions](#)
[System Requirements](#)