

O/26/101417 - Land adjacent to Windhover Roundabout, Bursledon

14/07/2026

Dear David,

This consultation response is in relation to access, and the provided information appears the same as for the Pre-application Enquiry, which was submitted last year. Therefore, our response will be the same for this Outline proposal as it was for the Pre application Enquiry.

The access on to the A3024 appears to be the principal HGV access and would require the removal of T18 (and T19 and G6 for widening). These losses are broadly acceptable, subject to replacement tree planting, which appears to be possible (although we would defer to the Landscape Officer for their expertise regarding appropriateness of tree planting locations).

Access on to West End Road does not involve direct tree loss, but it does appear to sit slightly south of the exiting access. This brings it closer to the semi-mature lime tree (T8). We have concerns that the growing lime tree could disrupt the surfaces via root growth and, ultimately, be removed. Can we ask why the access point appears to be in this position and can it be shifted slightly to the north? Our preference would be sacrifice part of G1 rather than put pressure on T8.

Finally, regarding internal access roads, there are no significant trees within the internals of the site and, therefore, we have no issues regarding internal roads shown on the proposed site layout.

Kind regards,

Chris