



Eastleigh Borough Council
Eastleigh House Upper Market Street
Eastleigh
SO50 9YN

Your ref
H/26/101657

Our ref
DSA000056180

Date
27th of July 2026

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Demolition of existing rear garage structure, erection of single storey rear extension.
Site: 64 KINGSWAY, CHANDLER'S FORD, EASTLEIGH, SO53 1FJ.

Thank you for your correspondence, please see our comments below regarding the above application.

No Objections

Southern Water has no objections to this proposal.

Please note, surface water should not be disposed of into a public foul sewer and must comply with the Hierarchy of H3 of the Building Regulations. For more details, refer to the Drainage and Waste Disposal: Approved Document H on the GOV.UK website.

Any new connections to the public sewerage system will require a New Sewer Connection application (also known as a Section 106) to be submitted and approved by Southern Water.

Proposed works involve demolition

In order to protect and safeguard the existing water supply apparatus, Southern Water requests formal notification of any proposed demolition works prior to such works being undertaken.

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.



For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119)

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team

southernwater.co.uk/developing-building/planning-your-development