

From: [Tim Dyer](#)
To: [Aftanas, Gina](#)
Subject: L/26/101907 - 9 Greyladyes, School Road, Bursledon, SO31 8BX.
Date: 31 August 2026 10:46:20

Gina,

No problem with the proposed essential works and while one would normally expect a structure of this age to be roofed in lead that would be unfair in this situation, particularly as the insurance companies will be taking a big hit this year and it is not generally seen anyway.

The roof currently has a lead flashing around the perimeter which should be either reinstated or replaced in accordance with best practice. Apart from that no objection.

Regards,
Tim.

--

Tim J S Dyer, B.Sc.,Dip.Arch.(Birm), Grad.Dip.Conservation(AA), RIBA.

[Built Heritage Consultant](#).

tel: 07413 992 763.