

**Altman, Rebecca**

---

**Subject:** FW: Botley Centre application ref. F/26/101437

---

**Sent:** 09 September 2026 09:19

**Subject:** RE: Botley Centre application ref. F/26/101437

Hi Rebecca,

I have reviewed the Demolition/ Refurbishment Asbestos Survey Report produced by Airsafe Surverys Ltd (02/09/2026). It indicates that a visual inspection was undertaken and some representative samples were collected for lab testing (corrugated roof sheet, mastic between wall panels and sink pad). The results show that no asbestos was detected in any of the samples analysed. The report does not include soil testing. Based on this, the proposed condition is no longer applicable.

Best regards,

Yacklin

**Yacklin Panza**

**Pollution Control Specialist**

Planning & Environment - Pollution

**Ext.: 8058**

**Mobile: 07557 327776**

---