



EasyComplianceTools

GUIDED WATER EFFICIENCY CALCULATOR REPORT

PART G WATER EFFICIENCY

Water Efficiency Certificate

Reference WEC-000212 • Issued 28-07-2026

PASS

PROPERTIES ASSESSED

2

PASS

2

FAIL

0

REPORT DETAILS

Assessment type	Water Efficiency Assessment	Plot / group	Barn C
Site	Mortimers Farm, Mortimers Lane, Fair Oak, Hampshire	Postcode	SO50 7EA
Assessor	Mortimers Farm Developments Limited		



CERTIFICATE SUMMARY

Property compliance summary

PROPERTY COMPLIANCE SUMMARY

PROPERTY / UNIT	CALCULATED USE	TARGET	DIFFERENCE TO TARGET	COMPLIANCE
Barn C — Barn	107.80 L/person/day	110.00 L/person/day	2.20 below target	PASS
Barn C — C	107.80 L/person/day	110.00 L/person/day	2.20 below target	PASS



CALCULATION DETAIL

Calculation details for Properties

Barn C — Barn

PASS

CALCULATED USE	TARGET	DIFFERENCE TO TARGET	COMPLIANCE
107.80 L/person/day	110.00 L/person/day	2.20 below target	PASS

This certificate records the calculated water consumption for the plot type based on the submitted fixture and system specifications. Result: PASS — the calculated consumption is below the selected Part G target.

House & occupancy inputs

Reference	Barn C
Bedrooms	3
Target (l/person/day)	110
Assumed occupancy used in calculation	2.40 persons
Approved Document G normalisation factor	0.91
System savings/adjustments	0.00 L/person/day

Calculation summary

Total calculated use before savings	112.91 L/person/day
Greywater saving	0.00 L/person/day
Rainwater saving	0.00 L/person/day
After greywater/rainwater savings	112.91 L/person/day
Approved Document G normalisation factor	×0.91
External water allowance	+5.00 L/person/day
Final calculated use	107.80 L/person/day
Target	110.00 L/person/day
Result	PASS

Submitted fixture and system specifications

Total number of toilets	3
-------------------------	---



Number of wash hand basins	3
Number of showers	2
Number of baths	1
Number of kitchen sinks	1
Number of utility sinks	0
Number of dishwashers	1
Number of washing machines	1
Greywater recycling	No
Rainwater harvesting	No
Waste disposal system	No
Water softener system	No
Comprehensive assumptions	No

Daily usage breakdown (litres/day)

WC	SHOWER	BATH	WASH HAND BASIN TAPS	KITCHEN/UTILITY TAPS	DISHWASHER	WASHING MACHINE
32.50	83.90	44.88	26.54	31.20	10.80	41.18

Add plot type details

Total Number of Toilets	3
Number of Wash Hand Basins	3
Number of Showers incl. Above Bath	2
Number of Baths	1
Number of Kitchen Sinks	1
Number of Utility Sinks	0
Number of Dishwashers	1
Number of Washing Machines	1
Are you recycling greywater?	No
Do you have a rainwater harvesting system?	No



PART G WATER EFFICIENCY

www.easycompliance tools.com

Assessment Ref: **WEC-000212**

Issued: 28-07-2026

Do you have a waste disposal system?	No
Do you have a water softener system?	No
Edit advanced fixture values?	No



Barn C — C

PASS

CALCULATED USE	TARGET	DIFFERENCE TO TARGET	COMPLIANCE
107.80 L/person/day	110.00 L/person/day	2.20 below target	PASS

This certificate records the calculated water consumption for the plot type based on the submitted fixture and system specifications. Result: PASS — the calculated consumption is below the selected Part G target.

House & occupancy inputs

Reference	Barn C
Bedrooms	3
Target (l/person/day)	110
Assumed occupancy used in calculation	2.40 persons
Approved Document G normalisation factor	0.91
System savings/adjustments	0.00 L/person/day

Calculation summary

Total calculated use before savings	112.91 L/person/day
Greywater saving	0.00 L/person/day
Rainwater saving	0.00 L/person/day
After greywater/rainwater savings	112.91 L/person/day
Approved Document G normalisation factor	×0.91
External water allowance	+5.00 L/person/day
Final calculated use	107.80 L/person/day
Target	110.00 L/person/day
Result	PASS

Submitted fixture and system specifications

Total number of toilets	3
Number of wash hand basins	3
Number of showers	2



Number of baths	1
Number of kitchen sinks	1
Number of utility sinks	0
Number of dishwashers	1
Number of washing machines	1
Greywater recycling	No
Rainwater harvesting	No
Waste disposal system	No
Water softener system	No
Comprehensive assumptions	No

Daily usage breakdown (litres/day)

WC	SHOWER	BATH	WASH HAND BASIN TAPS	KITCHEN/UTILITY TAPS	DISHWASHER	WASHING MACHINE
32.50	83.90	44.88	26.54	31.20	10.80	41.18

Add plot type details

Total Number of Toilets	3
Number of Wash Hand Basins	3
Number of Showers incl. Above Bath	2
Number of Baths	1
Number of Kitchen Sinks	1
Number of Utility Sinks	0
Number of Dishwashers	1
Number of Washing Machines	1
Are you recycling greywater?	No
Do you have a rainwater harvesting system?	No
Do you have a waste disposal system?	No
Do you have a water softener system?	No



Edit advanced fixture values?

No

METHOD

Method and standards

Building Regulations 2010 (Approved Document G)

The Water Supply (Water Fittings) Regulations 1999

Part G calculation methodology (l/person/day)

Figures are based on submitted assessment inputs and the Approved Document G water efficiency calculation methodology.