

F/26/101979 – Land at White Stork Road, Adjacent to the Roundabout with Winchester Road.

28/09/2026

UPDATE FOLLOWING SUBMISSION OF UPDATED ARBORICULTURAL INFORMATION

Dear Liz,

As the only external changes proposed are to the turning head, we raise no arboricultural objection subject to the following Condition:

The development must accord with the arboricultural report reference PRI24389aia_ams Rev G. No excavation, demolition or development related works shall commence until the tree protection measures have been installed as per the tree protection plan reference PRI24389-03 Rev F. Once installed, no access by vehicles or placement of goods, chemicals, fuels, soil or other materials shall take place within the protected area. Tree protection measures shall be retained in their approved form for the duration of the work and may only be modified subject to written agreement from the LPA. Reason - To retain and protect the existing trees which form an important part of the amenity of the locality.

15/09/2026

Dear Liz,

Arboricultural Documents:

- Arboricultural impact assessment and method statement reference PRI24389aia_ams Rev F dated 27/06/2025; and
- Tree protection plan reference PRI24389-03 Rev F dated 10/08/2026.

Firstly, a minor point, but one that will require clarifying before we comment: is the supplied arboricultural impact assessment and method statement revision 'F' or 'G'? The front cover information states 'F', but there is reference to 'G' within the document. 'G' would make sense as it has recently been updated, but we need this to be positively determined before conditioning a document based on the reference.

Kind regards,

Chris.