

MR CRAIG ROPPOLO
12 SPRINGFIELD DRIVE
TOTTON
SOUTHAMPTON
HAMPSHIRE
SO40 2QS

Application	H/26/101824
Please ask for	Gina Aftanas
Direct dial	023 8068 8426
Working hours	Mon to Fri 8:30am to 5pm
Email	gina.aftanas@eastleigh.gov.uk

Thursday 1 October 2026

Town and Country Planning Act 1990
The Town and Country Planning (Development Management Procedure) (England)
Order 2015

Application No. H/26/101824

In pursuance of their powers under the above Act and in accordance with your application received on Monday 27 July 2026 the Council, as Local Planning Authority hereby **Permit** the following :

Description: Single storey and first floor extensions to the rear and detached single storey garden room to rear garden.
Site: 7 BURNS ROAD, EASTLEIGH, SO50 5DW

Subject to due compliance with the following conditions:

- 1 The development hereby permitted shall start no later than three years from the date of this decision.

Reason: To comply with Section 91 of the Town and Country Planning Act 1990.

- 2 The development hereby permitted shall be implemented in accordance with the following plans numbered: block plan, location plan, 01, 02, 03 Rev A, 04 Rev B, 05 Rev A.

Reason: For the avoidance of doubt and in the interests of proper planning.

- 3 The materials to be used in the construction of the external surfaces of the development hereby permitted shall match in type, colour and texture those used on the adjoining building.

Reason: To ensure a satisfactory visual relationship between the new development and the existing.

Note to Applicant: In order to protect public sewers, Southern Water requests that if consent is granted, the following condition is attached to the planning permission; The developer must agree with Southern Water, prior to commencement of the development, the measures to be taken to protect the public sewers.

An investigation of the sewer is required to confirm its size and depth, ascertain its condition, number of properties served and potential means of access before any decision can be made as to whether it would be acceptable for the proposed development to be built close to the sewer. If the sewer in question is found to be no greater than 225mm in diameter and no deeper than 3 meters, the development may be allowed, subject to the following conditions:

1. No construction works parallel to the sewer within 500mm (in plan).
2. Where within three metres, foundations depth to be taken down 150mm below the invert level of the sewer.

In order to protect drainage apparatus, Southern Water requests that if consent is granted, the following condition is attached to the planning permission; prior to the commencement of development, the developer must advise the local authority, in consultation with Southern Water, of measures which will be undertaken to protect the public sewers.

Note to Applicant: In the unlikely event of any bats being found during demolition or construction, all work must stop immediately, and Natural England must be informed. Additional information is available on the Bat Conservation Trust website at <https://www.bats.org.uk/advice/im-working-on-a-building-with-bats/ive-found-a-bat-during-works>.

A precautionary working method must be used to prevent harm to wildlife that could be using this site.

It should include:

All building materials to be stored on hard standing or on pallets, as far as possible from hedgerows, scrub or potential habitat.

Any excavations must be covered at night or be fitted with a small animal escape ramp.

No fires can be lit on site.

Waste must be stored in a skip and not be allowed to accumulate in piles which could be used by wildlife. Any chemicals and fuels must be stored carefully and away from potential wildlife habitat. Any animals found on site should not be handled but be allowed to move away to a place of safety on their own.

Biodiversity enhancements will be required in accordance with Local Plan policy DM 11 and NPPF (December 2024) paragraphs 187d and 192 b. A bat box and a swift nest box may be appropriate for this building.

The Bat Conservation Trust recommends installing a bat brick/box at least 4 m above the ground, away from artificial light sources, sheltered from strong winds and exposed to the sun for part of the day, facing south, south-east or south-west. (<https://www.bats.org.uk/our-work/putting-up-your-box>)

Swift nest boxes are best positioned under the eaves or on walls facing north, northeast or north-west out of direct sunlight, five metres above the ground, with clear adjacent airspace so swifts can access them in a high-speed direct flight. (<https://www.swiftconservation.org/Nestboxes%26Attraction.htm>)

Note to Applicant: In accordance with paragraph 1 of policy DM3 within the National Planning Policy Framework (August 2026), Eastleigh Borough Council takes a positive manner to the handling of development proposals so as to achieve, whenever possible, a positive outcome and to ensure all proposals are dealt with in a timely manner.

Yours faithfully

A handwritten signature in black ink that reads "N Parker".

Nicholas Parker
Planning Manager

N.B. See Attached Notes