

Eastleigh Borough Council
Eastleigh House
Upper Market Street
Eastleigh
SO50 9YN

Hampshire 2050
The Castle
Winchester, Hampshire SO23 8UD

Telephone: 0300 555 1375
Fax: 01962 847055

www.hants.gov.uk

Enquiries To Matt Grantham

My reference 052605

Direct Line

Your reference A/24/96899

Date 5 March 2024

Email eastleighdc@hants.gov.uk

Dear Mr Osmond,

THE GEORGE, 492 FAIR OAK ROAD, FAIR OAK, EASTLEIGH, SO50 7AN

Display of 1no. externally illuminated hanging sign, 3no. externally illuminated letter signs, 3no. externally illuminated amenity board signs, 2no. externally illuminated chalkboard signs, 1no. non-illuminated signwritten logo sign, 7no. LED floodlights, and 4no. up and down lights

In regard to application A/24/96899, having reviewed the information contained within the application pack, there is no objection to the proposals from a highway perspective, subject to the condition outlined below.

All lighting sources are located on the building itself, and it is noted that light beams head towards the building (as opposed to away from the building which could be towards the highway), and the candela proposed is 200Cd/M which falls within guidance limits.

CONDITION

AMOUNT OF ILLUMINATION

The illumination of the consented sign(s) and floodlights shall be no greater than 200 candela per square metres and no light source shall be visible from the highway.

Reason: In the interests of highway safety/amenity.

Yours sincerely,

Matt Grantham

Director of Hampshire 2050
Garry Westbrook