

Surface water drainage response amended for F/23/95507 Willow Bee, Allington Lane, Eastleigh, SO30 3HP

Replacement entrance gate, hardstanding, and frontage fence (Retrospective).

Rachael Morris

I have reviewed the surface water drainage statement by Aqua Callidus (October 2023) and have no further concerns about surface water drainage changes with respect to this retrospective application for an entrance gate, frontage fence and hardstanding.

Lisa Malter

Ecologist

3/10/23

A clarification note on the existing drawings would be a good starting point for a surface water drainage diagram. From the photos it appears that previously vegetated surfaces have been paved with the *granular sub-base with an uncompacted stone topping*. Since this is a retrospective application, the changes to site surface water drainage have already been made. Arrows showing surface water exceedance flow when the ground is saturated should also be included.

Lisa Malter

Ecologist